

**GENERAL CONDITIONS AND  
TECHNICAL SPECIFICATIONS**

**for**

**Construction of**

**WATER SYSTEM IMPROVEMENTS**

**for the**

**CITY OF GALLATIN**

**In**

**SUMNER COUNTY, TENNESSEE**

**December 2022**

**JAMES C. HAILEY & COMPANY**

Consulting Engineers  
1619 Galleria Blvd  
Brentwood, TN 37027  
(615) 883-4933

**GENERAL CONDITIONS AND  
TECHNICAL SPECIFICATIONS**

for

Construction of

**WATER SYSTEM IMPROVEMENTS**

for the

**CITY OF GALLATIN**

in

**SUMNER COUNTY, TENNESSEE**

**December 2022**



DW20221401

**APPROVED WATER SPECIFICATIONS**

THE DOCUMENT BEARING THIS STAMP HAS BEEN RECEIVED AND REVIEWED BY THE

TENNESSEE DEPT. OF ENVIRONMENT & CONSERVATION

DIVISION OF WATER RESOURCES

AND IS HEREBY APPROVED FOR USE IN CONSTRUCTION BY THE COMMISSIONER

*Johanna McNeil*  
01/03/2023

THIS APPROVAL SHALL NOT BE CONSTRUED AS CREATING A  
PRESUMPTION OF CORRECT OPERATION OR AS WARRANTING BY THE  
COMMISSIONER THAT THE APPROVED FACILITIES WILL REACH THE  
DESIGNED GOALS.

**APPROVAL EXPIRES FIVE YEARS FROM ABOVE DATE**

**JAMES C. HAILEY & COMPANY**

Consulting Engineers

1619 Galleria Blvd.

Brentwood, TN 37027

(615) 883-4933

Project #22208

Set No. \_\_\_\_\_

**CITY OF GALLATIN  
WATER SYSTEM STANDARD SPECIFICATIONS - 2022**

**TABLE OF CONTENTS**

<b><u>DESCRIPTION</u></b>	<b><u>BEGINNING PAGE NUMBER</u></b>
General Conditions .....	GC-1
Special Conditions .....	SC-1

**TECHNICAL SPECIFICATIONS - WATER LINE ADDITIONS**

**SECTION 1 - SCOPE OF PROJECT**

1.01 General.....	TSW 1-1
-------------------	---------

**SECTION 2 - PRELIMINARY WORK**

2.01 General.....	TSW 2-1
2.02 Location & Protection of Underground Utilities .....	TSW 2-1
2.03 Surveying and Staking .....	TSW 2-1
2.04 Removal of Obstructions.....	TSW 2-1
2.05 Clearing and Grubbing.....	TSW 2-2

**SECTION 3 - MATERIALS**

3.01 General.....	TSW 3-1
3.02 Cement.....	TSW 3-1
3.03 Concrete Fine Aggregate .....	TSW 3-1
3.04 Concrete Coarse Aggregate .....	TSW 3-1
3.05 Water .....	TSW 3-1
3.06 Ready Mix Concrete .....	TSW 3-1
3.07 Class "A" Concrete .....	TSW 3-1
3.08 Class "B" Concrete .....	TSW 3-1
3.09 Metal Reinforcing.....	TSW 3-1
3.10 Crushed Stone.....	TSW 3-1
3.11 Pea Gravel.....	TSW 3-1
3.12 Ductile Iron Pipe .....	TSW 3-2
3.13 Plastic Water Pipe & Fittings .....	TSW 3-2
3.14 High Density Polyethylene .....	TSW 3-3
3.15 Ductile Iron Fittings .....	TSW 3-3
3.16 Gate Valves .....	TSW 3-3
3.17 Butterfly Valves (with underground operator) .....	TSW 3-4
3.18 Tapping Sleeves and Valves.....	TSW 3-5
3.19 Valve Boxes.....	TSW 3-5
3.20 Fire Hydrants .....	TSW 3-6
3.21 Casing Pipe .....	TSW 3-6
3.22 Cross-linked Polyethylene Water Pipe & Fittings.....	TSW 3-7
3.23 Service Installations .....	TSW 3-8
3.21.1 Fittings .....	TSW 3-8
3.21.2 Meter Box.....	TSW 3-8
3.21.3 Water Meters .....	TSW 3-8
3.21.4 Service Saddles .....	TSW 3-8
3.21.5 Copper Service Pipe .....	TSW 3-8
3.24 Marker Posts & Tracer Wire .....	TSW 3-8
3.25 Flowable Fill .....	TSW 3-7

**CITY OF GALLATIN**  
**WATER SYSTEM STANDARD SPECIFICATIONS - 2022**

**TECHNICAL SPECIFICATIONS - WATER LINE ADDITIONS** *(continued)*

<b><u>DESCRIPTION</u></b>	<b><u>BEGINNING PAGE NUMBER</u></b>
 <b><u>SECTION 4 - EXCAVATION AND BACKFILL</u></b>	
4.01 General.....	TSW 4-1
4.02 Classification of Excavation .....	TSW 4-1
4.03 Trench Excavation .....	TSW 4-1
4.04 Excavation for Structures .....	TSW 4-2
4.05 Rock Excavation .....	TSW 4-3
4.06 Removal of Water .....	TSW 4-4
4.07 Storage of Excavated Material .....	TSW 4-4
4.08 Disposal of Surplus Excavated Material .....	TSW 4-4
4.09 Backfill for Trenches .....	TSW 4-4
4.10 Acceptable Backfill Material .....	TSW 4-6
 <b><u>SECTION 5 - PAVEMENT REPLACEMENT</u></b>	
5.01 General.....	TSW 5-1
5.02 Pavement Removal.....	TSW 5-1
5.03 Pavement Replacement.....	TSW 5-1
 <b><u>SECTION 6 - INSTALLATION OF WATER PIPE AND ACCESSORIES</u></b>	
6.01 General.....	TSW 6-1
6.02 Handling Pipe and Accessories.....	TSW 6-1
6.03 Installation of Ductile Iron Pipe.....	TSW 6-1
6.04 Installation of Polyvinyl Chloride (PVC) Pipe .....	TSW 6-2
6.05 Installation of HDPE Pipe.....	TSW 6-2
6.06 Installing Fire Hydrants .....	TSW 6-3
6.07 Thrust Blocks or Restraints .....	TSW 6-3
6.08 Valve Box Installations .....	TSW 6-3
6.09 Connections to Existing Mains .....	TSW 6-4
6.10 Services, Service Replacements, & Service Reconnections .....	TSW 6-4
6.11 Protection of Pipe.....	TSW 6-4
6.12 Installation of pipe at Sewer Crossing .....	TSW 6-4
6.12 Installation of Flushing Points .....	TSW 6-5
 <b><u>SECTION 7 - TESTING AND DISINFECTION - WATER MAIN</u></b>	
7.01 General.....	TSW 7-1
7.02 Pressure and Leakage Tests... ..	TSW 7-1
7.03 Disinfection... ..	TSW 7-1
7.04 Flushing... ..	TSW 7-2
7.05 Testing and Disinfection Procedure.....	TSW 7-2

**CITY OF GALLATIN  
WATER SYSTEM STANDARD SPECIFICATIONS - 2022**

**TECHNICAL SPECIFICATIONS - WATER LINE ADDITIONS** *(continued)*

<b><u>DESCRIPTION</u></b>	<b><u>BEGINNING PAGE NUMBER</u></b>
<b><u>SECTION 8 - SPECIAL CONDITIONS</u></b>	
8.01 General.....	TSW 8-1
8.02 Work on Highway Right-of-Way.....	TSW 8-1
8.03 Work on Railroad Right-of-Way.....	TSW 8-1
8.04 Coordination with Other Utilities.....	TSW 8-1
8.05 Seeding.....	TSW 8-1
8.06 Casing Pipe.....	TSW 8-1
8.07 Service Relocations .....	TSW 8-2
8.08 Slope Protection & Erosion Control.....	TSW 8-2
8.09 Video .....	TSW 8-8
<b><u>SECTION 9 - WARRANTY AND MAINTENANCE OBLIGATIONS</u></b>	
9.01 Warranty .....	TSW 9-1
9.02 Maintenance Obligation.....	TSW 9-1

**CITY OF GALLATIN**  
**GENERAL CONDITIONS**

**TABLE OF CONTENTS**

<b><u>Title</u></b>	<b><u>Section</u></b>
DEFINITIONS .....	GC-01
ADDITIONAL INSTRUCTIONS AND DETAIL DRAWINGS.....	GC-02
SCHEDULES, REPORTS AND RECORDS .....	GC-03
DRAWINGS AND SPECIFICATIONS.....	GC-04
SHOP DRAWINGS .....	GC-05
MATERIALS, SERVICES AND FACILITIES.....	GC-06
INSPECTION AND TESTING .....	GC-07
SUBSTITUTIONS .....	GC-08
PATENTS .....	GC-09
SURVEYS, PERMITS, REGULATIONS .....	GC-10
PROTECTION OF WORK, PROPERTY, PERSONS.....	GC-11
SUPERVISION BY CONTRACTOR .....	GC-12
CHANGES IN THE WORK .....	GC-13
CHANGES IN THE CONTRACT PRICE .....	GC-14
TIME FOR COMPLETION AND LIQUIDATED DAMAGES .....	GC-15
CORRECTION OF WORK.....	GC-16
SUBSURFACE CONDITIONS .....	GC-17
SUSPENSION OF WORK, TERMINATION AND DELAY .....	GC-18
PAYMENTS TO CONTRACTOR.....	GC-19
ACCEPTANCE OF FINAL PAYMENT AS RELEASE.....	GC-20
INSURANCE.....	GC-21
CONTRACT SECURITY .....	GC-22
ASSIGNMENTS .....	GC-23
INDEMNIFICATION .....	GC-24
SEPARATE CONTRACTS .....	GC-25

**CITY OF GALLATIN**  
**GENERAL CONDITIONS**

**TABLE OF CONTENTS**

<b><u>Title</u></b>	<b><u>Section</u></b>
SUBCONTRACTING .....	GC-26
ENGINEERS AUTHORITY .....	GC-27
LAND AND RIGHTS-OF-WAY .....	GC-28
GUARANTY .....	GC-29
TAXES .....	GC-30



GC-1

**DEFINITIONS**

- GC-1.01      Wherever used in the **CONTRACT DOCUMENTS**, the following terms shall have the meanings indicated which shall be applicable to both the singular and plural thereof:
- GC-1.02      **ADDENDA** - Written or graphic instruments issued prior to the execution of the Agreement, which modify or interpret the **CONTRACT DOCUMENTS**, **DRAWINGS** and **SPECIFICATIONS**, by additions, deletions, clarifications or corrections.
- GC-1.03      **BID** - The offer or proposal of the **BIDDER** submitted on the prescribed form setting forth the prices for the **WORK** to be performed.
- GC-1.04      **BIDDER** - Any person, firm or corporation submitting a **BID** for the **WORK**.
- GC-1.05      **BONDS** - Bid, Performance, and Payment Bonds and other instruments of security, furnished by the **CONTRACTOR** and his security in accordance with the **CONTRACT DOCUMENTS**.
- GC-1.06      **CHANGE ORDER** - A written order to the **CONTRACTOR** authorizing an addition, deletion or revision in the **WORK** within the general scope of the **CONTRACT DOCUMENTS**, or authorizing an adjustment in the **CONTRACT PRICE** or **CONTRACT TIME**.
- GC-1.07      **CONTRACT DOCUMENTS** - The contract, including Advertisement for Bids, Information for Bidders, **BID**, Bid Bond, Agreement, Payment Bond, Performance Bond, **NOTICE TO AWARD**, **NOTICE TO PROCEED**, **CHANGE ORDER**, **DRAWINGS**, **SPECIFICATIONS**, and **ADDENDA**.
- GC-1.08      **CONTRACT PRICE** - The total monies payable to the **CONTRACTOR** under the terms and conditions of the **CONTRACT DOCUMENTS**.
- GC-1.09      **CONTRACT TIME** - The number of calendar days stated in the **CONTRACT DOCUMENTS** for the completion of the **WORK**.

## DEFINITIONS

GC-1.10 Thru 1.19

- GC-1.10     **CONTRACTOR** - The person, firm or corporation with whom the **OWNER** has executed the Agreement.
- GC-1.11     **DRAWINGS** - The part of the **CONTRACT DOCUMENTS**, which show the characteristics and scope of the **WORK** to be performed and which have been prepared or approved by the **ENGINEER**.
- GC-1.12     **ENGINEER** - The person, firm or corporation named as such in the **CONTRACT DOCUMENTS**.
- GC-1.13     **FIELD ORDER** - A written order effecting a change in the **WORK** not involving an adjustment in the **CONTRACT PRICE** or an extension of the **CONTRACT TIME**, issued by the **ENGINEER** to the **CONTRACTOR** during construction.
- GC-1.14     **NOTICE OF AWARD** - The written notice of the acceptance of the **BID** from the **OWNER** to the successful **BIDDER**.
- GC-1.15     **NOTICE TO PROCEED** - Written communication issued by the **OWNER** to the **CONTRACTOR** authorizing him to proceed with the **WORK** and establishing the date of commencement of the **WORK**.
- GC-1.16     **OWNER** - a public or quasi-public body or authority, corporation, association, partnership, or individual for whom the **WORK** is to be performed.
- GC-1.17     **PROJECT** - The undertaking to be performed as provided in the **CONTRACT DOCUMENTS**.
- GC-1.18     **RESIDENT PROJECT REPRESENTATIVE** - The authorized representative of the **OWNER** who is assigned to the **PROJECT** site or any part thereof.
- GC-1.19     **SHOP DRAWINGS** - All drawings, diagrams, illustrations, brochures, schedules, and other data which are prepared by the **CONTRACTOR**, a **SUBCONTRACTOR**, manufacturer, **SUPPLIER** or distributor, which illustrate how specific portions of the **WORK** shall be fabricated or installed.

## DEFINITIONS

GC-1.20 Thru 1.26

- GC-1.20     **SPECIFICATIONS** - A part of the **CONTRACT DOCUMENTS** consisting of written descriptions of a technical nature of materials, equipment, construction systems, standards and workmanship.
- GC-1.21     **SUBCONTRACTOR** - An individual, firm or corporation having a direct contract with the **CONTRACTOR** or with any other **SUBCONTRACTOR** for the performance of a part of the **WORK** at the site.
- GC-1.22     **SUBSTANTIAL COMPLETION** - That date as certified by the **ENGINEER** when the construction of the **PROJECT** or a specified part thereof is sufficiently completed, in accordance with the **CONTRACT DOCUMENTS**, so that the **PROJECT** or specified part can be utilized for the purposes for which it is intended.
- GC-1.23     **SUPPLEMENTAL GENERAL CONDITIONS** - Modifications to General Conditions required by a Federal agency for participation in the **PROJECT** and approved by the agency in writing prior to inclusion in the **CONTRACT DOCUMENTS**.
- GC-1.24     **SUPPLIERS** - Any person, supplier or organization who supplies materials or equipment for the **WORK**, including that fabricated to a special design, but who does not perform labor at the site.
- GC-1.25     **WORK** - All labor necessary to produce the construction required by the **CONTRACT DOCUMENTS**, and all materials and equipment incorporated or to be incorporated in the **PROJECT**.
- GC-1.26     **WRITTEN NOTICE** - Any notice to any party of the Agreement relative to any part of this Agreement in writing and considered delivered and the service thereof completed, when posted by certified or registered mail to the said party at his last given address, or delivered in person to said party or his authorized representative on the **WORK**.

GC-2

**ADDITIONAL INSTRUCTIONS AND DETAIL DRAWINGS**

GC-2.01      The **CONTRACTOR** may be furnished additional instructions and detail drawings, by the **ENGINEER**, as necessary to carry out the **WORK** required by the **CONTRACT DOCUMENTS**.

GC-2.02      The additional drawings and instruction thus supplied will become a part of the **CONTRACT DOCUMENTS**. The **CONTRACTOR** shall carry out the **WORK** in accordance with the additional detail drawings and instructions.

GC-3

**SCHEDULES, REPORTS AND RECORDS**

- GC-3.01 The **CONTRACTOR** shall submit to the **OWNER** such schedule of quantities and costs, progress schedules, payrolls, reports, estimates, records and data as the **OWNER** may request concerning **WORK** performed or to be performed.
- GC-3.02 Prior to the first partial payment estimate the **CONTRACTOR** shall submit schedules showing the order in which he proposes to carry on the **WORK**, including dates at which he will start the various parts of the **WORK**, estimated date of completion of each part and, as applicable:
- GC-3.2.1 the dates at which special detail drawings will be required; and
- GC-3.2.2 respective dates for submission of **SHOP DRAWINGS**, the beginning of manufacture, the testing and the installation of materials, supplies and equipment.
- GC-3.03 The **CONTRACTOR** shall also submit a schedule of payments that he anticipates he will earn during the course of the **WORK**.

**GC-4****DRAWINGS AND SPECIFICATIONS**

- GC-4.01 The intent of the **DRAWINGS** and **SPECIFICATIONS** is that the **CONTRACTOR** shall furnish all labor, materials, tools, equipment, and transportation necessary for the proper execution of the **WORK** in accordance with the **CONTRACT DOCUMENTS** and all incidental work necessary to complete the **PROJECT** in an acceptable manner, ready for use, occupancy or operation by the **OWNER**.
- GC-4.02 In case of conflict between the **DRAWINGS** and **SPECIFICATIONS** the **SPECIFICATIONS** shall govern. Figure dimensions on **DRAWINGS** shall govern over scale dimensions, and detailed **DRAWINGS** shall govern over general **DRAWINGS**.
- GC-4.03 Any discrepancies found between the **DRAWINGS** and **SPECIFICATIONS** and site conditions or any inconsistencies or ambiguities in the **DRAWINGS** and **SPECIFICATIONS** shall be immediately reported to the **ENGINEER**, in writing, who shall promptly correct such inconsistencies or ambiguities in writing. **WORK** done by the **CONTRACTOR** after his discovery of such discrepancies, inconsistencies or ambiguities shall be done at the **CONTRACTOR'S** risk.

## GC-5

SHOP DRAWINGS

- GC-5.01 The **CONTRACTOR** shall provide **SHOP DRAWINGS** as may be necessary for the prosecution of the **WORK** as required by the **CONTRACT DOCUMENTS**. The **ENGINEER** shall promptly review all **SHOP DRAWINGS**. The **ENGINEER'S** approval of any **SHOP DRAWING** shall not release the **CONTRACTOR** from responsibility for deviations from the **CONTRACT DOCUMENTS**. The approval of any **SHOP DRAWINGS**, which substantially deviates from the requirement of the **CONTRACT DOCUMENTS**, shall be evidenced by a **CHANGE ORDER**.
- GC-5.02 When submitted for the **ENGINEER'S** review, **SHOP DRAWINGS** shall bear the **CONTRACTOR'S** certification that he has reviewed, checked and approved the **SHOP DRAWINGS** and that they are in conformance with the requirements of the **CONTRACT DOCUMENTS**.
- GC-5.03 Portions of the **WORK** requiring a **SHOP DRAWING** or sample submission shall not begin until the **SHOP DRAWING** or submission has been approved by the **ENGINEER**. A copy of each approved **SHOP DRAWING** and each approved sample shall be kept in good order by the **CONTRACTOR** at the site and shall be available to the **ENGINEER**.

GC-6 MATERIALS, SERVICES, AND FACILITIES

- GC-6.01 It is understood that, except as otherwise specifically stated in the **CONTRACT DOCUMENTS**, the **CONTRACTOR** shall provide and pay for the materials, labor, tools, equipment, water, light, power, transportation, supervision, temporary construction of any nature, and all other services and facilities of any nature whatsoever necessary to execute, complete, and deliver the **WORK** within the specified time.
- GC-6.02 Materials and equipment shall be so stored as to insure the preservation of their quality and fitness for the **WORK**. Stored materials and equipment to be incorporated in the **WORK** shall be located so as to facilitate prompt inspection.
- GC-6.03 Manufactured articles, materials and equipment shall be applied, installed, connected, erected, used, cleaned and conditioned as directed by the manufacturer.
- GC-6.04 Materials, supplies and equipment shall be in accordance with samples submitted by the **CONTRACTOR** and approved by the **ENGINEER**.
- GC-6.05 Materials, supplies or equipment to be incorporated into the **WORK** shall not be purchased by the **CONTRACTOR** or the **SUBCONTRACTOR** subject to a chattel mortgage or under a conditional sale contract or other agreement by which an interest is retained by the seller.

GC-7 INSPECTIONS AND TESTING

- GC-7.01 All materials and equipment used in the construction of the **PROJECT** shall be subject to adequate inspection and testing in accordance with generally accepted standards.
- GC-7.02 The **CONTRACTOR** shall provide at his expense the necessary testing and inspection services required by the **CONTRACT DOCUMENTS**, unless otherwise provided.
- GC-7.03 The **OWNER** shall provide all other inspection and testing services not required by the **CONTRACT DOCUMENTS**.
- GC-7.04 If the **CONTRACT DOCUMENTS**, laws, ordinances, rules, regulations or orders of any public authority having jurisdiction require any **WORK** to specifically be inspected, tested, or approved by someone other than the **CONTRACTOR**, the **CONTRACTOR** will give the **ENGINEER** timely notice of readiness. The **CONTRACTOR** will then furnish the **ENGINEER** the required certificates of inspection, testing or approval.
- GC-7.05 Neither observations by the **ENGINEER** nor inspections, tests or approvals by persons other than the **CONTRACTOR** shall relieve the **CONTRACTOR** from his obligations to perform the **WORK** in accordance with the requirements of the **CONTRACT DOCUMENTS**.
- GC-7.06 The **ENGINEER** and his representatives will at all times have access to the **WORK**. In addition, authorized representatives and agents of any participating Federal or State agency shall be permitted to inspect the work, materials, payrolls, records of personnel, invoices of materials, and other relevant data and records. The **CONTRACTOR** will provide proper facilities for such access and observation of the **WORK** and also for any inspection, or testing thereof.
- GC-7.07 If any **WORK** is covered contrary to the written request of the **ENGINEER** it must, if requested by the **ENGINEER**, be uncovered for his observation and replaced at the **CONTRACTOR'S** expense.

GC-7.08      If the **ENGINEER** considers it necessary or advisable that covered **WORK** be inspected or tested by others, the **CONTRACTOR**, at the **ENGINEER'S** request, will uncover, expose or otherwise make available for observation, inspection or testing as the **ENGINEER** may require, that portion of the **WORK** in question, furnishing all necessary labor, materials, tools, and equipment. If it is found that such **WORK** is defective, the **CONTRACTOR** will bear all the expenses of such uncovering, exposure, observation, inspection and testing and of satisfactory reconstruction. If, however, such **WORK** is not found to be defective, the **CONTRACTOR** will be allowed an increase in the **CONTRACT PRICE** or an extension of the **CONTRACT TIME**, or both, directly attributable to such uncovering, exposure, observation, inspection, testing and reconstruction and an appropriate **CHANGE ORDER** shall be issued.

GC-8        **SUBSTITUTIONS**

GC-8.01        Whenever a material, article or piece of equipment is identified on the **DRAWINGS** or **SPECIFICATIONS** by reference to brand name or catalogue number, it shall be understood that this is referenced for the purpose of defining the performance or other salient requirements and that other products of equal capacities, quality and function shall be considered. The **CONTRACTOR** may recommend the substitution of a material, article, or piece of equipment of equal substance and function for those referred to in the **CONTRACT DOCUMENTS** by reference to brand name or catalogue number, and if, in the opinion of the **ENGINEER**, such material, article, or piece of equipment is of equal substance and function to that specified, the **ENGINEER** may approve its substitution and use by the **CONTRACTOR**. Any cost differential shall be deductible from the **CONTRACT PRICE** and the **CONTRACT DOCUMENTS** shall be appropriately modified by **CHANGE ORDER**.

The **CONTRACTOR** warrants that if substitutes are approved, no major changes in the function or general design of the **PROJECT** will result. Incidental changes or extra component parts required to accommodate the substitute will be made by the **CONTRACTOR** without a change in the **CONTRACT PRICE** or **CONTRACT TIME**.

**GC-9      PATENTS**

GC-9.01      The **CONTRACTOR** shall pay all applicable royalties and license fees. He shall defend all suits or claims for infringement of any patent rights and save **OWNER** harmless from loss on account thereof, except that the **OWNER** shall be responsible for any such loss when a particular process, design, or the product of a particular manufacturer or manufacturers is specified, but if the **CONTRACTOR** has reason to believe that the design, process or product specified is an infringement of a patent, he shall be responsible for such loss unless he promptly gives such information to the **ENGINEER**.

GC-10      **SURVEYS, PERMITS, REGULATIONS**

- GC-10.1      The **OWNER** shall furnish all boundary surveys and establish all base lines for locating the principal component parts of the **WORK** together with a suitable number of benchmarks adjacent to the **WORK** as shown in the **CONTRACT DOCUMENTS**. From the information provided by the **OWNER**, unless otherwise specified in the **CONTRACT DOCUMENTS**, the **CONTRACTOR** shall develop and make all detail surveys needed for construction such as slope stakes, batter boards, stakes for pile locations and other working points, lines, elevations and cut sheets.
- GC-10.02      The **CONTRACTOR** shall carefully preserve bench marks, reference points and stakes and, in case of willful or careless destruction, he shall be charged with the resulting expense and shall be responsible for any mistakes that may be caused by their unnecessary loss or disturbance.
- GC-10.03      Permits and licenses of a temporary nature necessary for the prosecution of the **WORK** shall be secured and paid for by the **CONTRACTOR**. Permits, licenses and easements for permanent structures or permanent changes in existing facilities shall be secured and paid for by the **OWNER**, unless otherwise specified. The **CONTRACTOR** shall give all notices and comply with all laws, ordinances, rules and regulations bearing on the conduct of the **WORK** as drawn and specified. If the **CONTRACTOR** observes that the **CONTRACT DOCUMENTS** are at variance therewith, he shall promptly notify the **ENGINEER** in writing, and any necessary changes shall be adjusted as provided in Section 13, **CHANGES IN THE WORK**.

GC-11      **PROTECTION OF WORK, PROPERTY AND PERSONS**

- GC-11.01      The **CONTRACTOR** will be responsible for initiating, maintaining and supervising all safety precautions and programs in connection with the **WORK**. He will take all necessary precautions for the safety of, and will provide the necessary protection to prevent damage, injury or loss to all employees on the **WORK** and other persons who may be affected thereby, all the **WORK** and all materials or equipment to be incorporated therein, whether in storage on or off the site, and other property at the site or adjacent thereto, including trees, shrubs, lawns, walks, pavements, roadways, structures and utilities not designated for removal, relocation or replacement in the courses of construction.
- GC-11.02      The **CONTRACTOR** will comply with all applicable laws, ordinances, rules, regulations and orders of any public body having jurisdiction. He will erect and maintain, as required by the conditions and progress of the **WORK**, all necessary safeguards for safety and protection. He will notify owners of adjacent utilities when prosecution of the **WORK** may affect them. The **CONTRACTOR** will remedy all damage, injury or loss to any property caused, directly or indirectly, in whole or in part, by the **CONTRACTOR**, any **SUBCONTRACTOR** or anyone directly or indirectly employed by any of them or anyone for whose acts any of them may be liable, except damage or loss attributable to the fault of the **CONTRACT DOCUMENTS** or to the acts or omissions of the **OWNER** or the **ENGINEER** or anyone employed by either of them or anyone for whose acts either of them may be liable, and not attributable, directly or indirectly, in whole or in part, to the fault or negligence of the **CONTRACTOR**.
- GC-11.03      In emergencies affecting the safety of persons or the **WORK** or property at the site or adjacent thereto, the **CONTRACTOR**, without special instruction or authorization from the **ENGINEER** or **OWNER**, shall act to prevent threatened damage, injury or loss. He will give the **ENGINEER** prompt **WRITTEN NOTICE** of any significant changes in the **WORK** or deviations from the **CONTRACT DOCUMENTS** caused thereby, and a **CHANGE ORDER** shall thereupon be issued covering the changes and deviations involved.

GC-12      **SUPERVISION BY CONTRACTOR**

GC-12.01      The **CONTRACTOR** will supervise and direct the **WORK**. He will be solely responsible for the means, methods, techniques, sequences and procedures of construction. The **CONTRACTOR** will employ and maintain on the **WORK** a qualified supervisor or superintendent who shall have been designated in writing by the **CONTRACTOR** as the **CONTRACTOR'S** representative at the site. The supervisor shall have full authority to act on behalf of the **CONTRACTOR** and all communications given to the supervisor shall be as binding as if given to the **CONTRACTOR**. The supervisor shall be present on the site at all times as required to perform adequate supervision and coordination of the **WORK**.

GC-13      CHANGES IN THE WORK

GC-13.01      The **OWNER** may at any time, as the need arises, order changes within the scope of the **WORK** without invalidating the Agreement. If such changes increase or decrease the amount due under the **CONTRACT DOCUMENTS**, or in the time required for performance of the **WORK**; an equitable adjustment shall be authorized by **CHANGE ORDER**.

GC-13.02      The **ENGINEER**, also, may at any time, by issuing a **FIELD ORDER**, make changes in the details of the **WORK**. The **CONTRACTOR** shall proceed with the performance of any changes in the **WORK** so ordered by the **ENGINEER** unless the **CONTRACTOR** believes that such **FIELD ORDER** entitles him to a change in **CONTRACT PRICE** or **TIME**, or both, in which event he shall give the **ENGINEER WRITTEN NOTICE** thereof within seven (7) days after the receipt of the ordered change. Thereafter the **CONTRACTOR** shall document the basis for the change in **CONTRACT PRICE** or **TIME** within thirty (30) days. The **CONTRACTOR** shall not execute such changes pending the receipt of an executed **CHANGE ORDER** or further instructions from the **OWNER**.

GC-14      **CHANGES IN CONTRACT PRICE**

GC-14.01      The **CONTRACT PRICE** may be changed only by a **CHANGE ORDER**. The value of any **WORK** covered by a **CHANGE ORDER** or of any claim for increase or decrease in the **CONTRACT PRICE** shall be determined by one or more of the following methods in the order of precedence listed below:

- (a)      Unit prices previously approved.
- (b)      An agreed lump sum.
- (c)      The actual cost for labor, direct overhead, materials, supplies, equipment, and other services necessary to complete the work. In addition there shall be added an amount to be agreed upon but not to exceed fifteen percent (15%) of the actual cost of the **WORK** to cover the cost of general overhead and profit.

GC-15      **TIME FOR COMPLETION AND LIQUIDATED DAMAGES**

- GC-15.01      The date of beginning and the time for completion of the **WORK** are essential conditions of the **CONTRACT DOCUMENTS** and the **WORK** embraced shall be commenced on a date specified in the **NOTICE TO PROCEED**.
- GC-15.02      The **CONTRACTOR** will proceed with the **WORK** at such rate of progress to insure full completion within the **CONTRACT TIME**. It is expressly understood and agreed, by and between the **CONTRACTOR** and the **OWNER**, that the **CONTRACT TIME** for the completion of the **WORK** described herein is a reasonable time, taking into consideration the average climatic and economic conditions and other factors prevailing in the locality of the **WORK**.
- GC-15.03      If the **CONTRACTOR** shall fail to complete the **WORK** within the **CONTRACT TIME**, or extension of time granted by the **OWNER**, then the **CONTRACTOR** will pay to the **OWNER** the amount of liquidated damages as specified in the **BID** for each calendar day that the **CONTRACTOR** shall be in default after the time stipulated in the **CONTRACT DOCUMENTS**.
- GC-15.04      The **CONTRACTOR** shall not be charged with liquidated damages or any excess cost when the delay in completion of the **WORK** is due to the following, and the **CONTRACTOR** has promptly given **WRITTEN NOTICE** of such delay to the **OWNER** or **ENGINEER**.

15.4.1 To any preference, priority or allocation order duly issued by the **OWNER**.

15.4.2 To unforeseeable causes beyond the control and without the fault or negligence of the **CONTRACTOR**, including but not restricted to, acts of God, or of the public enemy, acts of the **OWNER**, acts of another **CONTRACTOR** in the performance of a contract with the **OWNER**, fires, floods, epidemics, quarantine restrictions, strikes, freight embargoes, and abnormal and unforeseeable weather; and

15.4.3 To any delays of **SUBCONTRACTORS** occasioned by any of the causes specified in paragraphs 15.4.1 and 15.4.2 of this article.

GC-16      **CORRECTION OF WORK**

- GC-16.01      The **CONTRACTOR** shall promptly remove from the premises all **WORK** rejected by the **ENGINEER** for failure to comply with the **CONTRACT DOCUMENTS**, whether incorporated in the construction or not, and the **CONTRACTOR** shall promptly replace and re-execute the **WORK** in accordance with the **CONTRACT DOCUMENTS** and without expense to the **OWNER** and shall bear the expense of making good all **WORK** of other **CONTRACTORS** destroyed or damaged by such removal or replacement.
- GC-16.02      All removal and replacement **WORK** shall be done at the **CONTRACTOR'S** expense. If the **CONTRACTOR** does not take action to remove such rejected **WORK** within ten (10) days after receipt of **WRITTEN NOTICE**, the **OWNER** may remove such **WORK** and store the materials at the expense of the **CONTRACTOR**.

GC-17      **SUBSURFACE CONDITIONS**

GC-17.01      The **CONTRACTOR** shall promptly, and before such conditions are disturbed, except in the event of an emergency, notify the **OWNER** by **WRITTEN NOTICE** of:

17.1.1 Subsurface or latent physical conditions at the site differing materially from those indicated in the **CONTRACT DOCUMENTS**; or

17.1.2 Unknown physical conditions at the site, of an unusual nature, differing materially from those ordinarily encountered and generally recognized as inhering in **WORK** of the character provided for in the **CONTRACT DOCUMENTS**.

GC-17.02      The **OWNER** shall promptly investigate the conditions, and if he finds that such conditions do so materially differ and cause an increase or decrease in the cost of, or in the time required for, performance of the **WORK** an equitable adjustment shall be made and the **CONTRACT DOCUMENTS** shall be modified by a **CHANGE ORDER**. Any claim of the **CONTRACTOR** for adjustment hereunder shall not be allowed unless he has given the required **WRITTEN NOTICE**; provided that the **OWNER** may, if he determined the facts so justify, consider and adjust any such claims asserted before the date of final payment.

GC-18      **SUSPENSION OF WORK, TERMINATION AND DELAY**

- GC-18.01      The **OWNER** may, at any time and without cause, suspend the **WORK** or any portion thereof for a period of not more than ninety (90) days or such further time as agreed upon by the **CONTRACTOR**, by **WRITTEN NOTICE** to the **CONTRACTOR** and the **ENGINEER** which notice shall fix the date on which **WORK** shall be resumed. The **CONTRACTOR** will resume that **WORK** on the date so fixed. The **CONTRACTOR** will be allowed an increase in the **CONTRACT PRICE** or an extension of the **CONTRACT TIME**, or both, directly attributable to any suspension.
- GC-18.02      If the **CONTRACTOR** is adjudged a bankrupt or insolvent, or if he makes a general assignment for the benefit of his creditors, or if a trustee or receiver is appointed for the **CONTRACTOR** or for any of his property, or if he files a petition to take advantage of any debtor's act, or to recognize under the bankruptcy or applicable laws, or if he repeatedly fails to supply sufficient skilled workmen or suitable materials or equipment, or if he repeatedly fails to make prompt payment to **SUBCONTRACTORS** or for labor, materials or equipment or if he disregards laws, ordinances, rules, regulations or orders of any public body having jurisdiction of the **WORK** or if he disregards the authority of the **ENGINEER**, or if he otherwise violates any provision of the **CONTRACT DOCUMENTS**, then the **OWNER** may, without prejudice to any other right or remedy and after giving the **CONTRACTOR** and his surety a minimum of ten (10) days from delivery of a **WRITTEN NOTICE**, terminate the services of the **CONTRACTOR** and take possession of the **PROJECT** and of all materials, equipment, tools, construction equipment and machinery thereon owned by the **CONTRACTOR** and finish the **WORK** by whatever method he may deem expedient.

In such case the **CONTRACTOR** shall not be entitled to receive any further payment until the **WORK** is finished. If the unpaid balance of the **CONTRACT PRICE** exceeds the direct and indirect the **CONTRACTOR** and take possession of the **PROJECT** and all materials, equipment, tools, construction equipment and machinery thereon owned by the **CONTRACTOR**, and finish the **WORK** by whatever costs of completing the **PROJECT**, including compensation for additional professional services, such excess shall be paid to the **CONTRACTOR**. If such costs exceed such unpaid balance, the **CONTRACTOR** will pay the difference to the **OWNER**. Such costs incurred by the **OWNER** will be determined by the **ENGINEER** and incorporated in a **CHANGE ORDER**.

GC-18.03 Where the **CONTRACTOR'S** services have been so terminated by the **OWNER**, said termination shall not affect any right of the **OWNER** against the **CONTRACTOR** then existing or which may thereafter accrue. Any retention or payment of monies by the **OWNER** due the **CONTRACTOR** will not release the **CONTRACTOR** from compliance with the **CONTRACT DOCUMENTS**.

GC-18.04 After ten (10) days from delivery of **WRITTEN NOTICE** to the **CONTRACTOR** and the **ENGINEER**, the **OWNER** may, without cause and without prejudice to any other right or remedy, elect to abandon the **PROJECT** and terminate the Contract. In such case, the **CONTRACTOR** shall be paid for all **WORK** executed and any expense sustained plus reasonable profit.

- GC-18.05 If, through no act or fault of the **CONTRACTOR**, the **WORK** is suspended for a period of more than ninety (90) days by the **OWNER** or under an order of court or other public authority, or the **ENGINEER** fails to act on any request for payment within thirty (30) days after it is submitted, or the **OWNER** fails to pay the **CONTRACTOR** substantially the sum approved by the **ENGINEER** or awarded by arbitrators within thirty (30) days of its approval and presentation, then the **CONTRACTOR** may, after ten (10) days from delivery of a **WRITTEN NOTICE** to the **OWNER** and the **ENGINEER**, terminate the **CONTRACT** and recover from the **OWNER** payment for all **WORK** executed and all expenses sustained. In addition and in lieu of terminating the **CONTRACT**, if the **ENGINEER** has failed to act on a request for payment or if the **OWNER** has failed to make any payment as aforesaid, the **CONTRACTOR** may upon ten (10) days notice to the **OWNER** and the **ENGINEER** stop the **WORK** until he has been paid all amounts then due, in which event and upon resumption of the **WORK**, **CHANGE ORDERS** shall be issued for adjusting the **CONTRACT PRICE** or extending the **CONTRACT TIME** or both to compensate for the costs and delays attributable to the stoppage of the **WORK**.
- GC-18.06 If the performance of all or any portion of the **WORK** is suspended, delayed, or interrupted as a result of a failure of the **OWNER** or **ENGINEER** to act within the time specified in the **CONTRACT DOCUMENTS**, or if no time is specified, within a reasonable time, an adjustment in the **CONTRACT PRICE** or an extension of the **CONTRACT TIME**, or both, shall be made by **CHANGE ORDER** to compensate the **CONTRACTOR** for the costs and delays necessarily caused by the failure of the **OWNER** or **ENGINEER**.

GC-19      PAYMENT TO CONTRACTOR

GC-19.01      At least ten (10) days before each progress payments falls due (but not more often than once a month), the **CONTRACTOR** will submit to the **ENGINEER** a partial payment estimate filled out and signed by the **CONTRACTOR** covering the **WORK** performed during the period covered by the partial payment estimate and supported by such data as the **ENGINEER** may reasonably require. If payment is requested on the basis of materials and equipment not incorporated in the **WORK** but delivered and suitably stored at or near the site, the partial payment estimate shall also be accompanied by such supporting data, satisfactory to the **OWNER**, as will establish the **OWNER'S** title to the material and equipment and protect his interest therein, including applicable insurance. The **ENGINEER** will, within ten (10) days after receipt of each partial payment estimate, either indicate in writing his approval of payment and present partial payment estimate to the **OWNER**, or return the partial payment estimate to the **CONTRACTOR** indicating in writing his reasons to approve payment. In the latter case, the **CONTRACTOR** may make the necessary corrections and resubmit the partial payment estimate. The **OWNER** will within fifteen (15) days of presentation to him of an approved partial payment estimate, pay the **CONTRACTOR** a progress payment on the basis of the approved partial payment estimate less the retainage. The retainage shall be an amount equal to ten percent (10%) of said estimate until fifty percent (50%) of the **WORK** has been completed.

At fifty percent (50%) completion, further partial payments shall be made in full to the **CONTRACTOR** and no additional amounts may be retained unless the **ENGINEER** certifies that the job is not proceeding satisfactorily, but amounts previously retained shall not be paid to the **CONTRACTOR**. At fifty percent (50%) completion or any time thereafter when the progress of the **WORK** is not satisfactory additional amounts may be retained but in no event shall the total retainage be more than ten percent (10%) of the value of the **WORK** completed. Upon substantial completion of the **WORK**, any amount retained may be paid to the **CONTRACTOR**. When the **WORK** has been substantially completed except for work which cannot be completed because of weather conditions, lack of materials or other reasons which in the judgment of the **OWNER** are valid reasons for noncompletion, the **OWNER** may make additional payments, retaining at all times an amount sufficient to cover the estimated cost of the **WORK** still to be completed.

- GC-19.02      The request for payment may also include an allowance for the cost of such major materials and equipment, which are suitably stored either at or near the site.
- GC-19.03      Prior to **SUBSTANTIAL COMPLETION**, the **OWNER**, with the approval of the **ENGINEER** and with the concurrence of the **CONTRACTOR**, may use any completed or substantially completed portions of the **WORK**. Such use shall not constitute an acceptance of such portions of the **WORK**.
- GC-19.04      The **OWNER** shall have the right to enter the premises for the purpose of doing work not covered by the **CONTRACT DOCUMENTS**. This provision shall not be construed as relieving the **CONTRACTOR** of the sole responsibility for the care and protection of the **WORK**, or the restoration of any damaged **WORK** except such as may be caused by agents or employees of the **OWNER**.

- GC-19.05 Upon completion and acceptance of the **WORK**, the **ENGINEER** shall issue a certificate attached to the final payment request that the **WORK** has been accepted by him under the conditions of the **CONTRACT DOCUMENTS**. The entire balance found to be due the **CONTRACTOR**, including the retained percentages, but except such sums as may be lawfully retained by the **OWNER** shall be paid to the **CONTRACTOR** within thirty (30) days of completion and acceptance of the **WORK**.
- GC-19.06 The **CONTRACTOR** will indemnify and save the **OWNER** or the **OWNER'S** agents harmless from all claims growing out of the lawful demand of **SUBCONTRACTORS**, laborers, workmen, mechanics, materialmen, and furnishers of machinery and parts thereof, equipment, tools, and all supplies, incurred in the furtherance of the performance of the **WORK**. The **CONTRACTOR** shall, at the **OWNER'S** request, furnish satisfactory evidence that all obligations of the nature designated above have been paid, discharged, or waived. If the **CONTRACTOR**, fails to do so the **OWNER** may, after having notified the **CONTRACTOR**, either pay unpaid bills or withhold from the **CONTRACTOR'S** unpaid compensation a sum of money deemed reasonably sufficient to pay any and all such lawful claims until satisfactory evidence is furnished that all liabilities have been fully discharged whereupon payment to the **CONTRACTOR** shall be resumed in accordance with the terms of the **CONTRACT DOCUMENTS**, but in no event shall the provisions of this sentence be construed to impose any obligations upon the **OWNER** to either the **CONTRACTOR**, his Surety, or any third party. In paying any unpaid bills of the **CONTRACTOR**, any payment so made by the **OWNER** shall be considered as a payment made under the **CONTRACT DOCUMENTS** by the **OWNER** to the **CONTRACTOR** and the **OWNER** shall not be liable to the **CONTRACTOR** for any such payment made in good faith.
- GC-19.07 If the **OWNER** fails to make payment thirty (30) days after approval by the **ENGINEER**, in addition to other remedies available to the **CONTRACTOR**, there shall be added to each such payment interest at the maximum legal rate commencing on the first day after said payment is due and continuing until the payment is received by the **CONTRACTOR**.

GC-20      ACCEPTANCE OF FINAL PAYMENT AS RELEASE

GC-20.01      The acceptance by the **CONTRACTOR** of final payment shall be and shall operate as a release to the **OWNER** of all claims and all liability to the **CONTRACTOR** other than claims in stated amounts as may be specifically excepted by the **CONTRACTOR** for all things done or furnished in connection with this **WORK** and for every act and neglect of the **OWNER** and others relating to or arising out of this **WORK**. Any payment, however, final or otherwise, shall not release the **CONTRACTOR** or his sureties from any obligations under the **CONTRACT DOCUMENTS** or the Performance Bond and Payment Bonds.

GC-21      **INSURANCE**

GC-21.01      The **CONTRACTOR** shall purchase and maintain such insurance as will protect him from claims set forth below which may arise out of or result from the **CONTRACTOR'S** executions of the **WORK**, whether such execution be by himself or by any **SUBCONTRACT** or by anyone directly employed by any of them, or by anyone for whose acts any of them may be liable.

21.1.1 Claims under workmen's compensation, disability benefit and other similar employee benefit acts;

21.1.2 Claims for damages because of bodily injury, occupational sickness or disease, or death of his employees;

21.1.3 Claims for damages because of bodily injury, sickness or disease, or death of any person other than his employees;

21.1.4 Claims for damages insured by usual personal injury liability coverage which are sustained (1) by any person as a result of an offense directly or indirectly related to the employment of such person by the **CONTRACTOR**, or (2) by any other person; and

21.1.5 Claims for damages because of injury to or destruction of tangible property, including loss of use resulting therefrom.

GC-21.02      Certificates of Insurance acceptable to the **OWNER** shall be filed with the **OWNER** prior to commencement of the **WORK**. These Certificates shall contain a provision that coverages afforded under the policies will not be cancelled unless at least fifteen (15) days prior **WRITTEN NOTICE** has been given to the **OWNER**.

GC-21.03      The **CONTRACTOR** shall procure and maintain, at his own expense, during the **CONTRACT TIME**, liability insurance as hereinafter specified;

## INSURANCE

## GC-21.3.1 Thru 21.04

21.3.1 **CONTRACTOR'S** General Public Liability and Property Damage Insurance including vehicle coverage issued to the **CONTRACTOR** and protecting him from all claims for personal injury, including death, and all claims for destruction of our damage to property, arising out of or in connection with any operations under the **CONTRACT DOCUMENTS**, whether such operations be by himself or by any **SUBCONTRACTOR** under him, or anyone directly or indirectly employed by the **CONTRACTOR** or by a **SUBCONTRACTOR** under him. Insurance shall be written with the following limits of liability:

General Aggregate	\$2,000,000
Products/Completed	
Operations Aggregate	\$2,000,000
Per Occurrence	\$2,000,000
Fire Legal Liability	\$ 500,000
Medical Payments	\$ 5,000

21.3.2 The **CONTRACTOR** shall acquire and maintain, if applicable, Fire and Extended Coverage insurance upon the **PROJECT** to the full insurable value thereof for the benefit of the **OWNER**, the **CONTRACTOR**, and **SUBCONTRACTORS** as their interest may appear. This provision shall in no way release the **CONTRACTOR** or **CONTRACTOR'S** surety from obligations under the **CONTRACT DOCUMENTS** to fully complete the **PROJECT**.

GC-21.04 The **CONTRACTOR** shall procure and maintain, at his own expense, during the **CONTRACT TIME**, in accordance with the provisions of the laws of the state in which the work is performed, Workmen's Compensation Insurance, including occupational disease provisions, for all of his employees at the site of the **PROJECT** and in case any work is sublet, the **CONTRACTOR** shall require such **SUBCONTRACTOR** similarly to provide Workmen's Compensation Insurance, including occupational disease provisions for all of the latter's employees unless such employees are covered by the protection afforded by the **CONTRACTOR**. In case any class of employees engaged in hazardous work under this contract at the site of the **PROJECT** is not protected under Workmen's Compensation statute, the **CONTRACTOR** shall provide, and shall cause each **SUBCONTRACTOR** to provide, adequate and suitable insurance for the protection of his employees not otherwise protected.

GC-21.05     The **CONTRACTOR** shall secure, if applicable, "All Risk" type Builders Risk Insurance for **WORK** to be performed. Unless specifically authorized by the **OWNER**, the amount of such insurance shall not be less than the **CONTRACT PRICE** totaled in the bid. The policy shall cover not less than the losses due to fire, explosion, hail, lightning, vandalism, malicious mischief, wind, collapse, riot, aircraft, and smoke during the **CONTRACT TIME**, and until the **WORK** is accepted by the **OWNER**. The policy shall name as the insured the **CONTRACTOR**, the **ENGINEER**, and the **OWNER**.

GC-22 CONTRACT SECURITY

GC-22.01 The **CONTRACTOR** shall within ten (10) days after the receipt of the **NOTICE OF AWARD** furnish the **OWNER** with a Performance Bond and a Payment Bond in the penal sums equal to the amount of the **CONTRACT PRICE**, conditioned upon the performance by the **CONTRACTOR** of all undertakings, covenants, terms, conditions and agreements of the **CONTRACT DOCUMENTS**, and upon the prompt payment by the **CONTRACTOR** to all persons supplying labor and materials in the prosecution of the **WORK** provided by the **CONTRACT DOCUMENTS**. Such **BONDS** shall be executed by the **CONTRACTOR** and a corporate bonding company licensed to transact such business in the state in which the **WORK** is to be performed and named on the current list of "Surety Companies Acceptable on Federal Bonds" as published in the Treasury Department Circular Number 570. The expense of these **BONDS** shall be borne by the **CONTRACTOR**. If at any time a surety on any such **BOND** is declared bankrupt or loses its right to do business in the state in which the **WORK** is to be performed or is removed from the list of Surety Companies accepted on Federal **BONDS**, **CONTRACTOR** shall within ten (10) days after notice from the **OWNER** to do so, substitute an acceptable **BOND** (or **BONDS**) in such form and sum and signed by such other surety or sureties as may be satisfactory to the **OWNER**. The premiums on such **BOND** shall be paid by the **CONTRACTOR**. No further payments shall be deemed due nor shall be made until the new surety or sureties shall have furnished an acceptable **BOND** to the **OWNER**.

GC-23

**ASSIGNMENTS**

GC-23.01 Neither the **CONTRACTOR** nor the **OWNER** shall sell, transfer, assign or otherwise dispose of the Contract or any portion thereof, or of his right, title or interest therein, or his obligations thereunder, without written consent of the other party.

GC-24      **INDEMNIFICATION**

- GC-24.01      The **CONTRACTOR** will indemnify and hold harmless the **OWNER** and the **ENGINEER** and their agents and employees from and against all claims, damages, losses and expenses including attorneys' fees arising out of or resulting from the performance of the **WORK**, provided that any such claims, damage, loss or expense is attributable to bodily injury, sickness, disease or death, or injury to or destruction of tangible property, including the loss of use resulting therefrom; and is caused in whole or in part by any negligent or willful act or omission of the **CONTRACTOR**, and **SUBCONTRACTOR**, anyone directly or indirectly employed by any of them or anyone for whose acts any of them may be liable.
- GC-24.02      In any and all claims against the **OWNER** or the **ENGINEER**, or any of their agents or employees, by any employee of the **CONTRACTOR**, and **SUBCONTRACTOR**, anyone directly or indirectly employed by any of them, or anyone for whose acts any of them may be liable, the indemnification obligation shall not be limited in any way by any limitation on the amount or type of damages, compensation or benefits payable by or for the **CONTRACTOR** or any **SUBCONTRACTOR** under workmen's compensation acts, disability benefit acts or other employee benefits acts.
- GC-24.03      The obligation of the **CONTRACTOR** under this paragraph shall not extend to the liability of the **ENGINEER**, his agents or employees arising out of the preparation or approval of maps, **DRAWINGS**, opinions, reports, surveys, **CHANGE ORDERS**, designs or **SPECIFICATIONS**.

GC-25      SEPARATE CONTRACTS

- GC-25.01      The **OWNER** reserves the right to let other contracts in connection with this **PROJECT**. The **CONTRACTOR** shall afford other **CONTRACTORS** reasonable opportunity for the introduction and storage of their materials and the execution of their **WORK**, and shall properly connect and coordinate his **WORK** with theirs. If the proper execution or results of any part of the **CONTRACTOR'S WORK** depends upon the **WORK** of any other **CONTRACTOR**, the **CONTRACTOR** shall inspect and promptly report to the **ENGINEER** any defects in such **WORK** that render it unsuitable for such proper execution and results.
- GC-25.02      The **OWNER** may perform additional **WORK** related to the **PROJECT** by himself, or he may let other contracts containing provisions similar to these. The **CONTRACTOR** will afford the other **CONTRACTORS** who are parties to such Contracts (or the **OWNER**, if he is performing the additional **WORK** himself), reasonable opportunity for the introduction and storage of materials and equipment and the execution of **WORK**, and shall properly connect and coordinate his **WORK** with theirs.
- GC-25.03      If the performance of additional **WORK** by other **CONTRACTORS** or the **OWNER** is not noted in the **CONTRACT DOCUMENTS** prior to the execution of the **CONTRACT**, written notice thereof shall be given to the **CONTRACTOR** prior to starting any such additional **WORK**. If the **CONTRACTOR** believes that the performance of such additional **WORK** by the **OWNER** or others involves him in additional expense or entitles him to an extension of the **CONTRACT TIME**, he may make a claim thereof as provided in Sections 14 and 15.

GC-26      **SUBCONTRACTING**

- GC-26.01      The **CONTRACTOR** may utilize the services of specialty **SUBCONTRACTORS** on those parts of the **WORK** which, under normal contracting practices, are performed by specialty **CONTRACTORS**.
- GC-26.02      The **CONTRACTOR** shall not award **WORK** to **SUBCONTRACTOR(S)**, in excess of fifty percent (50%) of the **CONTRACT PRICE**, without prior written approval of the **OWNER**.
- GC-26.03      The **CONTRACTOR** shall be fully responsible to the **OWNER** for the acts and omissions of his **SUBCONTRACTORS**, and of persons either directly or indirectly employed by them, as he is for the acts and omissions of persons directly employed by him.
- GC-26.04      The **CONTRACTOR** shall cause appropriate provisions to be inserted in all subcontracts relative to the **WORK** to bind **SUBCONTRACTORS** to the **CONTRACTOR** by the terms of the **CONTRACT DOCUMENTS** insofar as applicable to the **WORK** of **SUBCONTRACTORS** and to give the **CONTRACTOR** the same power as regards terminating any subcontract that the **OWNER** may exercise over the **CONTRACTOR** under any provision of the **CONTRACT DOCUMENTS**.
- GC-26.05      Nothing contained in this **CONTRACT** shall create any contractual relation between any **SUBCONTRACTOR** and the **OWNER**.

## GC-27

ENGINEERS AUTHORITY

- GC-27.01 The **ENGINEER** shall act as the **OWNER'S** representative during the construction period. He shall decide questions, which may arise as to quality and acceptability of materials furnished and **WORK** performed. He shall interpret the intent of the **CONTRACT DOCUMENTS** in a fair and unbiased manner. The **ENGINEER** will make visits to the site and determine if the **WORK** is proceeding in accordance with the **CONTRACT DOCUMENTS**.
- GC-27.02 The **CONTRACTOR** will be held strictly to the intent of the **CONTRACT DOCUMENTS** in regard to the quality of materials, workmanship and execution of the **WORK**. Inspections may be made at the factory or fabrication plant of the source of material supply.
- GC-27.03 The **ENGINEER** will not be responsible for the construction means, controls, techniques, sequences, procedures, or construction safety.
- GC-27.04 The **ENGINEER** shall promptly make decisions relative to interpretation of the **CONTRACT DOCUMENTS**.

GC-28      LAND AND RIGHTS-OF-WAY

- GC-28.01      Prior to issuance of **NOTICE TO PROCEED**, the **OWNER** shall obtain all land and rights-of-way necessary for carrying out and for the completion of the **WORK** to be performed pursuant to the **CONTRACT DOCUMENTS**, unless otherwise mutually agreed.
- GC-28.02      The **OWNER** shall provide to the **CONTRACTOR** information, which delineates and describes the lands owned and right-of-way acquired.
- GC-28.03      The **CONTRACTOR** shall provide at his own expense and without liability to the **OWNER** any additional land and access thereto that the **CONTRACTOR** may desire for temporary construction facilities, or for storage of materials.

GC-29

GUARANTY

GC-29.01 The **CONTRACTOR** shall guarantee all materials and equipment furnished and **WORK** performed for a period of one (1) year from the date of **SUBSTANTIAL COMPLETION**. The **CONTRACTOR** warrants and guarantees for a period of one (1) year from the date of **SUBSTANTIAL COMPLETION** of the system that the completed system is free from all defects due to fault materials or workmanship and the **CONTRACTOR** shall promptly make such corrections as may be necessary by reason of such defects including the repairs of any damage to other parts of the system resulting from such defects. The **OWNER** will give notice of observed defects with reasonable promptness. In the event that the **CONTRACTOR** should fail to make such repairs, adjustments, or other **WORK** that may be made necessary by such defects, the **OWNER** may do so and charge the **CONTRACTOR** the cost thereby incurred. The Performance Bond shall remain in full force and effect through the guarantee period.

## TAXES

GC-30.01 Thru 30.01

GC-30

### TAXES

GC-30.01 The **CONTRACTOR** will pay all sales, consumer, use and other similar taxes required by the law of the place where the **WORK** is performed.

## **SPECIAL CONDITIONS**

### **1. QUALIFICATIONS OF BIDDER**

The apparent low bidder shall submit to the **OWNER** a list and description of work performed on previous projects similar to this along with evidence of financial ability, including a list of equipment owned, to satisfactorily complete the project, if requested by the **OWNER**.

### **2. SUBCONTRACTORS AND SUPPLIERS**

In accordance with paragraph GC-26 of the **General Conditions** the **CONTRACTOR** shall submit a list of any Subcontractors and major material suppliers proposed on this project.

### **3. CONTRACT SECURITY**

Contract Security shall be provided as set out in the **Information for Bidders** and in accordance with paragraph GC-22 of the **General Conditions**.

### **4. CONTRACTOR'S AND SUBCONTRACTOR'S PUBLIC LIABILITY, AUTOMOBILE LIABILITY AND PROPERTY DAMAGE INSURANCE**

With reference to Section GC-21 of the **General Conditions**, the **CONTRACTOR** is advised that he shall purchase and maintain at his own expense Property Insurance as will protect the **CONTRACTOR** and the **OWNER** from loss or damage while the project is under construction and prior to full acceptance thereof by the **OWNER**.

### **5. ESTIMATE FOR PARTIAL PAYMENT**

Form FHA 424-18 "**Partial Payment Estimate**", shall be used when estimating periodic payment due the **CONTRACTOR**. The applications for progress or final payments by the **CONTRACTOR** will be submitted to the **ENGINEER** on or before the 5th day of each calendar month. The date at which receipt of partial payment by **ENGINEER** as stipulated in **General Conditions** (GC-19) is hereby set as the 5th day of the month provided estimates are received by such time. The partial payment estimate shall be for work performed no later than the last day of the preceding calendar month.

6. **CONTRACTOR - WITHDRAWAL OF RETAINED FUNDS**

The **GENERAL CONTRACTOR**, subcontractor and material suppliers waive all rights to withdrawal of retained funds, which may accrue under Tennessee Code Annotated 12-434.

**TECHNICAL SPECIFICATIONS****CITY OF GALLATIN****STANDARD WATER SPECIFICATIONS****SECTION 1 - SCOPE OF PROJECT**

- 1.01 **GENERAL** - The work to be accomplished under these Specifications consists of the furnishing of all materials, machinery, labor, equipment and services necessary for the construction of water line addition more particularly described elsewhere in the Specifications and shown on the Plans.

The **CONTRACTOR** shall perform all necessary clearing, staking, excavating, backfilling, grading, clean-up, restoration of damage to property, testing, etc., for the proper and complete installation of the system and restoration of the surface to its original condition.

**SECTION 2 - PRELIMINARY WORK****2.01 GENERAL**

- A. No construction shall commence until plans are approved by the Tennessee Department of Environment and Conservation and said approved plans are on site.
- B. In addition, no construction shall commence until a **Notice to Proceed** letter has been received from the District.

**2.02 LOCATION AND PROTECTION OF UNDERGROUND UTILITIES** - Prior to trenching, the **CONTRACTOR** shall determine, insofar as possible, the actual location of all underground utilities in the vicinity of his operations and shall have the respective utilities clearly mark their location so that they may be avoided by equipment operators. As per Tennessee State Law, a minimum of 72 hours before excavation is to begin, the **CONTRACTOR** shall call the **Tennessee One Call System at 1-800-351-111** to have member utilities mark their utilities. Please note that non-member utilities will have to be contacted individually. Where such utility lines or services appear to lie in the path of construction they shall be uncovered in advance to determine the exact location and depth and to avoid damage due to trenching operations. Existing facilities shall be protected during construction or removed and replaced in equal condition, as necessary.

Should any existing utility line or service be damaged during or as a result of the **CONTRACTOR'S** operations, the **CONTRACTOR** shall take such emergency measures as may be necessary to minimize damage and shall immediately notify the utility involved. The **CONTRACTOR** shall then repair the damage to the satisfaction of the utility or shall pay the utility for making the repairs. In all cases, the restoration and/or repair shall be such that the damaged structure will be in as good or better condition as before the damage occurred.

**2.03 SURVEYING AND STAKING** - The plans show the desired location of the water mains and it shall be the responsibility of the **CONTRACTOR** to provide the necessary stakes and lines to insure that the water mains will be actually installed in the location shown. Graphic symbols are used to indicate valve and hydrant general locations but **ARE NOT** drawn to scale. Minor changes in pipe line location to avoid obstructions or provide better coordination with topographic conditions may be worked out in the field between representatives of the **CONTRACTOR** and the **ENGINEER**. In general such field changes shall be limited to occasional deflections to avoid side drains, culverts, ditches, or other obstructions or lateral shifts which would result in an improved laying condition or a decrease in inconvenience to property owners or motorists.

It is intended that the water main be held a reasonable uniform distance from rights-of-way, edge of pavement, or other boundary and indiscriminate wandering over the available area solely for the purpose of selecting the easiest trenching conditions will not be tolerated.

Once the proposed location of the pipeline has been established the **CONTRACTOR** shall provide sufficient stakes and lines to guide the equipment operators and insure that the trenching will be done to proper alignment.

**2.04 REMOVAL OF OBSTRUCTIONS** - The **CONTRACTOR** shall be responsible for the removal, safeguarding and replacement of fences, walls, structures, culverts, street signs, billboards, shrubs, mailboxes, or other obstruction, which must be moved to facilitate construction. Such obstructions must be restored to at least their original condition.

- 2.05 **CLEARING AND GRUBBING** - The **CONTRACTOR** shall be responsible for cutting, removing and disposing of all trees, brush, stumps, roots and weeds within the construction area. Disposal shall be by means of chippers, landfills, or other approved method not in conflict with State or local ordinances.

Care shall be taken to avoid unnecessary cutting or damage to trees not in the construction area. The **CONTRACTOR** will be responsible for loss or damage to trees outside the permanent easement or rights-of-ways.

**SECTION 3 - MATERIALS**

- 3.01 **GENERAL** - All materials to be incorporated in the project shall be first quality, new and undamaged material conforming to all applicable portions of these specifications.

All materials must be furnished by the **CONTRACTOR**, and with all applicable taxes paid by the **CONTRACTOR**, and must conform to applicable portions of these specifications.

- 3.02 **CEMENT** - Cement shall be Portland cement of a brand approved by the **ENGINEERS** and shall conform to "**Standard Specifications for Portland Cement**", Type 1, ASTM Designation C150, latest revision. Cement shall be furnished in undamaged 94 pound, one (1) cubic foot sacks, and shall show no evidence of lumping.
- 3.03 **CONCRETE FINE AGGREGATE** - Fine aggregate shall be clean, hard uncoated natural sand conforming to ASTM Designation C33, latest revision, "**Standard Specifications for Concrete Aggregate**".
- 3.04 **CONCRETE COARSE AGGREGATE** - Coarse aggregate shall consist of clean, hard, dense particles of stone or gravel conforming to ASTM Designation C33, latest revision, "**Standard Specifications for Concrete Aggregate**". Aggregate shall be well graded between 1- 1/2" and #4 sieve sizes.
- 3.05 **WATER** - Water used in mixing concrete shall be clean and free from organic matter, pollutants and other foreign materials.
- 3.06 **READY MIX CONCRETE** - Ready-mix concrete shall be secured only from a source approved by the **ENGINEERS**, and shall conform to ASTM Designation C94, latest revision, "**Specifications for Ready-Mix Concrete**". Before any concrete is delivered on the job site, the supplier must furnish a statement of the proportions of cement, fine aggregate and coarse aggregate to be used for each mix ordered, and must receive the **ENGINEERS** approval of such proportions.
- 3.07 **CLASS "A" CONCRETE** - Class A concrete shall have a minimum compressive strength of 3500 pounds per square inch in 28 days and shall contain not less than 6 sacks of cement per cubic yard.
- 3.08 **CLASS "B" CONCRETE** - Class B concrete shall have a minimum compressive strength of 2000 pounds per square inch in 28 days and shall contain not less than 4 1/2 sacks of cement per cubic yard.
- 3.09 **METAL REINFORCING** - Reinforcing bars shall be Grade 60 steel conforming to ASTM Designation A615, latest revision, "Standard Specifications for Billet Steel Bars for Concrete Reinforcement". Bars shall be deformed with a cross sectional area at all points equal to that of plain bars of equal nominal size.
- 3.10 **CRUSHED STONE** - Crushed stone for bedding or backfill shall be Tennessee Department of Transportation Standard Size No. 67 and shall meet State Highway Department Standards for road surfacing.
- 3.11 **PEA GRAVEL** - Pea gravel for shaping cradle bedding shall be #4 to 1/2" size Ohio River, or approved local gravel of similar character.

- 3.12 **DUCTILE IRON PIPE** - Ductile iron pipe for water shall be manufactured in accordance with ANSI A21.51, AWWA C151 for centrifugally cast ductile iron pipe. The pipe shall be manufactured of iron having acceptance values of 60-42-10. The City of Gallatin requires that pipe larger than eight inches shall be minimum pressure class or thickness class 52 for diameter 0-16" and Class 350 for diameters greater than 16"

Pipe shall be furnished in lengths of 18' to 20' and unless otherwise indicated, shall be provided with a compression type slip joint equal to the Fastite joint as manufactured by American or approved equal. Gaskets and lubricant shall be furnished with the pipe.

Where restrained joints are required to resist thrust due to internal pressure, AMERICAN Fast-Grip, AMERICAN Flex-Ring, or AMERICAN Lok-Ring joints, or approved equal, shall be utilized at the specified locations. Restrained joints shall be rated for a working pressure of 250-psi minimum. All pipe installed in casing pipe shall be restrained joint.

Pipe shall be furnished with standard thickness cement lining on the inside with a bituminous seal coat and a bituminous coating on the outside. Cement lining shall conform to ANSI A21.4. The exterior of the pipe shall be clearly marked to indicate the manufacturer, date of manufacture, the pipe class and weight. Exterior markings shall also positively identify the pipe as being Ductile Iron.

- 3.13 **PLASTIC WATER PIPE & FITTINGS – (EIGHT INCH (8")) AND UNDER ONLY)** All plastic water pipe shall be made from clean, virgin, NSF-approved, Type I, Grade I polyvinyl chloride (PVC), conforming to ASTM resin specification D-1784. All pipe shall meet or exceed minimum requirements of ASTM D-2241 for type 1120 material made to pressure ratings or SDR classifications as called for on the Bid Proposal or minimum SDR-21 or DR-18 wall thickness. Samples of pipe and joints shall be submitted to **ENGINEER** along with physical and chemical data sheets for his approval before purchase of pipe.

Pipe length shall not exceed 40 feet unless approved by **ENGINEER**. Provision must be made for proper transporting, handling and storage of pipe. Pipe and fittings are to be assembled with non-toxic lubricant as recommended by manufacturer and approved by **ENGINEER**. Pipe shall be as manufactured by Consolidated Pipe & Supply, Vulcan Plastic Corporation, North American Pipe Corporation, Extrusion Technologies, Inc., Napco Manufacturing Corporation or equal.

Pipe joints shall be the coupling or bell and spigot type utilizing rubber ring compression gasket(s) (ASTM F477). Provision shall be made for thermal expansion and contraction to be taken up at the joint. Pipe joint shall conform to ASTM D-3139 latest revision.

Fittings shall be Ductile Iron (M.J.) and approved by **ENGINEER**. Proper adapters shall be used when connecting to piping of different material or dimensions, as approved by **ENGINEER**. Fittings shall have pressure ratings at least equal to that of connected piping. The end of the pipe installed in all fittings, valves, hydrants, etc., shall **not** be beveled but shall be square cut.

Manufacturer shall have pipe tested in accordance with provisions of applicable ASTM Specification. Manufacturer shall furnish **ENGINEERS** upon request, three (3) copies of certified statement to the effect that all items have met or exceeded requirements of the applicable specification. Test certificates will be required unless noted otherwise on drawings and shall cover all pipe used on this project.

### 3.13 **PLASTIC WATER PIPE & FITTINGS** (continued)

All pipe and fittings shall be subjected to a rigid inspection after delivery to the site, and before being placed in the work. Any item found defective by such field inspection will be rejected and shall be immediately removed from the premises. Marking shall include the following on each length of pipe: manufacturer's name, nominal size, class pressure rating, "PVC 1120", and NSF seal of approval. All pipe furnished shall be marked in accordance with ASTM D-2241.

All pipe shall have tracer wire (see Section 3.22) installed onto or near the pipe and a metallic tape or similar device installed not more than 18" above the pipe and in accordance with manufacturer's recommendation. The metallic device shall be Terra Tape or approved equal and shall be compatible with City location equipment.

### 3.14 **HIGH-DENSITY POLYETHYLENE** - The physical properties of high-density polyethylene (HDPE) pipe are described using ASTM D 3350-05, "Standard Specification Polyethylene Plastic Pipe and Fittings Materials.

HDPE pipe is made from resin with a cell classification of PE 345464C. The pipe is labeled as PE 3408/3608. The physical properties for PE 345464C are:

Table 3.3

PROPERTY VALUE	SPECIFICATION	UNIT	NOMINAL VALUE
<b>Material Designation</b>	PP/ASTM	-	PE 3408
<b>Material Designation</b>	PP/ASTM	-	PE 3408/3608
<b>Cell Classification</b>	ASTM D 3350	-	345464C
<i>Density</i> (3)	ASTM D 1505	g/cm3	0.941-0.943
<i>Melt Index</i> (4)	ASTM D 1238	gm/10min	0.05-.11
<i>Flexural Modulus</i> (5)	ASTM D 790	psi	110,000 to 140,000
<i>Tensile Strength</i> (4)	ASTM D 638	psi	3,200
<b>Slow Crack Growth</b>			
<i>ESCR</i>	ASTM D 1693	hours in 100% igepal	>5,000
<i>PENT</i> (6)	ASTM F 1473	hours	>100
<b>HDB@ 73 F</b> (4)	ASTM D 2837	psi	1,600
<b>UV Stabilizer</b> (C)	ASTM D 1603	%C	2 to 2.5%

HDPE Pipe used in the water system shall have a minimum pressure class rating of 200 psi (DR-11) unless otherwise specified by the department. HDPE pipe shall be provided with a blue identifier stripe. Stripe shall be integral to the pipe from the factory. No externally applied striping material shall be accepted.

### 3.15 **DUCTILE IRON FITTINGS** - All fittings shall be ductile iron manufactured in accordance with ANSI/AWWA 153/A21.53-94. Fittings shall be furnished with mechanical joints conforming to ANSI/AWWA C111/A21.11 and shall be cement lined with bituminous coating in accordance with ANSI/AWWA C104/A21.4. All fittings shall be furnished for 350 psi pressure rating. No full bodied fittings will be accepted unless otherwise directed.

All fittings shall be installed with mechanical restraint joints. Ductile iron pipe shall be EBAA Iron Sales, Inc. Series 1100, Tyler Union TUF Grip or approved equal, and PVC restraints shall be EBAA Iron Sales, Inc, Series 2000 PV, Tyler Union TUF Grip or approved equal.

- 3.16 **GATE VALVES** - All gate valves shall be resilient seated, manufactured to meet or exceed the requirement of AWWA C509 latest revision. All internal and external exposed surfaces shall be fusion-bonded epoxy coated with an approved epoxy coating to a minimum thickness of 6 mils, complying fully with AWWA 550 and certified to NSF61. Valves shall be furnished with mechanical joint ends in accordance with ANSI A21.11 unless otherwise shown or directed. Valve installations complete shall include an appropriate restrained gland joint for connection to piping.

Valves shall be suitable for installation in an approximate vertical position in buried pipelines. Stem seal shall consist of three (3) O-ring seals. All valves shall open to the left (counterclockwise) with non-rising stems and shall be provided with a 2-inch square operating nut. Gate valves shall be Mueller 2360 service resilient wedge gate valve or equal.

Valves shall be complete when shipped and the manufacturer shall use due and customary care in preparing them for shipment so as to avoid damage in handling or in transit. Particular care shall be taken to see that all valves are completely closed before shipment.

All valves shall be installed with mechanical restraint joints. Ductile iron pipe shall be EBAA Iron Sales, Inc. Series 1100, Tyler Union TUF Grip or approved equal, and PVC restraints shall be EBAA Iron Sales, Inc. Series 2000 PV, Tyler Union TUF Grip or approved equal.

- 3.17 **BUTTERFLY VALVES (with underground operator)** - All butterfly valves shall be of the tight closing, rubber-seat type that fully complies with the latest revision of AWWA Standard C504 where applicable. Valves shall be bubble-tight at rated pressures in either direction, and shall be satisfactory for applications involving throttling service and/or operation and for applications involving valve operation after long periods of inactivity. Valve discs shall rotate 90° from the full open position to the tight shut position. Regardless of valve size, angular mis-position of disc can be 1° off center without leakage. The manufacturer shall have manufactured tight-closing, rubber-seat butterfly valves for a period of at least five (5) years.

All valve bodies shall be cast iron ASTM A-126 Class B, narrow body design. Flange drilling shall be in accordance with ANSI B16.1 standard for cast iron flanges. Body thickness shall be in strict accordance with AWWA C504 where applicable.

All valve discs shall be constructed either of cast iron ASTM A-48 with stainless steel seating edge or ductile iron ASTM A-536 with stainless steel seating edge. The disc shall not have any hollow chambers that can entrap water. All surfaces shall be visually inspected and measurable to assure all structural members are at full design strength. Disc and shaft connection shall be made with stainless steel pins.

All shafts shall be turned, ground and polished and constructed of 18-8 Type 304 or Type 316 stainless steel. Shafts shall be two-piece, stub-type keyed for operator connection. Shaft diameters shall meet minimum requirements established by latest revision of AWWA Standard C504 for their class where applicable.

All seats shall be of a synthetic rubber compound. Seats shall be a full 360° without interruption and have a plurality of grooves mating with a spherical disc edge-seating surface. Valve seats shall be field adjustable around the full 360° circumference and replaceable without dismantling operator, disc or shaft and without removing the valve from the line. Manufacturer shall certify that rubber seat is field replaceable.

3.17 **BUTTERFLY VALVES (with underground operator)** (continued)

All valves shall be fitted with sleeve-type bearings. Bearings shall be corrosion resistant and self-lubricating. Bearing load shall not exceed 1/5 of the compressible strength of the bearing or shaft material.

Valve operators shall conform to AWWA Standard C504 and shall be designed to hold the valve in any intermediate position between full open and fully closed without creeping and fluttering.

Hydrostatic and leakage tests shall be conducted in strict accordance with AWWA Standard C504.

The manufacturer furnishing valves under the specification shall be prepared to show proof that the valves proposed meet the design requirements of AWWA Standard C504. Butterfly valves shall be Pratt Triton XR-70, Mueller Linesal III, M & H 4500, DeZurik or approved equal.

- 3.18 **TAPPING SLEEVES AND VALVES** - For all pipes less than ten inches (20") in diameter, a stainless steel tapping sleeve shall be used and shall consist of a stainless steel tapping sleeve and a valve with a flange outlet. For all pipes 20-inch (20") thru 24-inch (24") in diameter, OR where any pipe greater than 10-inch (10") or larger is proposed to have a tap of the same diameter as the main (example a 12-inch tap on a 12" main) tapping sleeves shall consist of a full body mechanical joint tapping sleeve and a valve with a flange outlet. For all pipes greater than 30-inches (30") in diameter the tapping sleeve shall be Cascade Style CST-EX Extra Heavy rated at 200 psi working pressure or approved equal. All valves shall conform to all applicable specifications for gate valves. In addition, all tapping sleeves shall be subject to an air "check test" prior to hydrostatically testing per manufacturer's instruction for warranty purposes. Mechanical joint tapping sleeves shall be Clow F-5205, M & H Style 1174, Mueller H-615 or approved equal. Stainless steel tapping sleeves shall be Ford FAST or approved equal.

- 3.19 **VALVE BOXES** – Valve boxes for the water distribution system shall be made of concrete as shown in the standard details and shall be of the heavy roadway type. Base section shall be enlarged to enclose and protect valve-operating nut without being in contact with the valve or the pipe at any point. Top section shall be adjustable for elevation. Backfill around valves and box shall be tamped to maintain proper alignment of the box. Valve boxes that are not plumb or not properly centered will not be accepted.

All valve boxes shall be provided with covers on which the word "WATER" is cast in raised letters. Boxes shall be suitable for installation on mains laid at depths specified. Additional compensation will not be provided for deeper valve boxes made necessary by installation of mains at depths greater than minimum depths specified.

Valve boxes shall have an inside opening of not less than 11" by 13". Standard precast reinforced concrete boxes having the same opening shall be. Concrete boxes and footing blocks shall be made of 4,500 psi concrete by an approved manufacturer.

Cast iron valve boxes shall be Model 8006, Roadway Type, Nashville Standard, as manufactured by an John Bouchard and Sons or pre-approved equal.

- 3.20 **FIRE HYDRANTS** - Fire hydrants shall be iron bodied fully bronze mounted, hydrants manufactured to equal or exceed AWWA Standard C502-54. Hydrants shall be suitable for 150 psi working pressure and shall be subjected to a test pressure of 300 psi. Inlet connection shall be 6" mechanical joint. Main hydrant valve shall be compression type, closing with the pressure, with 5 1/4" valve opening. The hydrant shall have a 7.5" I.D. barrel. The bronze seat shall be threaded into mating threads of bronze for easy field removal.

All hydrants shall be equipped with two (2) 2½" hose nozzles, one pumper nozzle, breakable safety flange, and stem coupling. Bronze nozzles shall be securely locked to prevent them from blowing off. Hose and pumper nozzles shall be field replaceable. Hose threads shall be National Standard. Nozzle caps shall be equipped with non-kink chains.

Hydrants shall be of the "dry head" type with an oil or grease reservoir and provision for automatic lubrication of stem threads and bearing surfaces each time the hydrant is operated. Double O-ring seals shall be provided to keep water out of the hydrant top. Operating nut style shall be 1½" pentagon with direction of opening to the left and shall be equipped with a weather cap. The operating nut, main stem, coupling and main valve assembly shall be capable of withstanding input torque of 200 ft/lbs., in opening or closing directions.

Hydrants shall be provided with multi-port drain ports. A positive stop shall be provided on the operating stem to prevent over travel when operating valve. It should not be necessary to excavate to repair or inspect internal parts. It should be removable without disturbing line joint or nozzle section of hydrant.

Fire hydrants shall be supplied with a bituminous coating for buried portion of hydrant and a yellow enamel finish for above ground portions of the hydrant.

All hydrants shall be installed with mechanical restraint joints. Ductile iron pipe shall be EBAA Iron Sales, Inc. Series 1100, Tyler Union TUF Grip or approved equal, and PVC restraints shall be EBAA Iron Sales, Inc, Series 2000 PV, Tyler Union TUF Grip or approved equal.

- 3.21 **CASING PIPE** - Where called for on the drawings, water pipe shall be installed in casing pipe. Casing pipe shall be black steel pipe with minimum wall thickness as follows:

<b><u>Pipe Diameter</u></b>	<b><u>Wall Thickness</u></b>
6"	0.250"
8"	0.250"
10"	0.250"
12"	0.250"
14"	0.312"
16"	0.375"
18"	0.375"
20"	0.375"
24"	0.375"
30"	0.375"

### 3.22 **CROSS-LINKED POLYETHEYLENE (PEX) WATER PIPE & FITTINGS –**

All PEX water pipe up to two inches (2") in diameter shall be:

- Service pipe to be cross-linked polyethylene (PEXa) piping manufactured using the high-pressure peroxide (Engel) method of cross-linking, with an approved cell classification of 354400 in accordance with ASTM D 3350, and a minimum degree of cross-linking of 70% in accordance with ASTM D 2765, Method B.
- Pipe to be certified to standards ASTM F 876, ASTM F 870, CSA B137.5, NSF 14, NSF 61, and PPI TR-4, by approved testing agencies.
- Pipe to have a minimum chlorine resistance as tested in accordance with ASTM F 2023 and specified in ASTM 876.
- Pipe to have a standard materials designation code of 1006, as certified by the PPI.
- Pipe to be certified to AWWA C 904 "Cross-linked Polyethylene (PEX) Pressure Pipe", ½ in. through 3 in., for Water Service" by approved testing agencies.
- Pipe to be manufactured in an ISO 9001 certified production facility.
- Approved temperature and pressure ratings to be from Table 3.1 and 3.2 below based on PPI Hydrostatic Design Basis as certified by CSA and NSF.

Table 3.1

Pressure (psi/kPa)	Temperature (°F/°C)
475/3310	73.4/23
210/1450	180/82.2
180/1240	200/93.3

Table 3.2

Pressure (psi/kPa)	Temperature (°F/°C)
160/1105	73.4/23
100/690	180/82.2
80/550	200/93.3

Provision must be made for proper transporting, handling, and storage of pipe. Pipe and fittings are to be as recommended by manufacturer and approved by **ENGINEER**. (Pipe shall be as manufactured by Wirsbo Aquapex or Endot Endopure or approved equal.)

Piping shall carry the following markings every three (3) feet: manufacturer's name or trademark, nominal size, 1006 (materials designation code), ASTM F 876, F 877, F 2023, CSA B137.5, NSF-PW, PEXa (material designation), SDR9 (standard dimension ratio), 160 psi @ 73.4°F, 100 psi @ 180°F, POTABLE TUBING, manufacturing date and machine number, and footage mark.

For 1-inch and 1 1/2- inch pipe use plastic insert on all compression fittings and for 2-inch use stainless steel insert on all compression fittings.

Pipe to be shipped in protective cardboard boxes or containers clearly marked with size and product name.

### 3.22 **CROSS-LINKED POLYETHEYLENE (PEX) WATER PIPE & FITTINGS (cont)–**

**Installation and Warranty** – Pipe shall be installed according to manufacturer's instructions and engineer's specifications in accordance with AWWA C-904 and local codes. Pipe shall be connected with approved AWWA C-800 compression joint valves and fittings, suitable for buried applications, using stainless steel support liners inside pipe at each joint. The pipe shall be completely buried or protected by opaque conduit unless installed indoors out of sunlight.

Pipe manufacturer shall warrant the cross-linked polyethylene service pipe to be free from defects in material and workmanship for a period of twenty-five (25) years.

### 3.23 **SERVICE INSTALLATIONS**

3.23.1 **Fittings** – All fittings shall be made of brass meeting AWWA C800, ASTM B584 and ANSI B16.15, containing No lead. Corporation stop shall be FORD FB-1000, or approved equal. Curb Stop shall be FORD B44-233W-Q-NL Meter copper setter shall be FORD VB 72-7W-41-33-Q-NL or approved equal. Meter coupling on customer side shall be FORD C38-23-3-NL or approved equal.

3.23.2 **Meter Box** - Meter Boxes shall be plastic, 24" minimum depth, rectangular plastic box with rectangular cast iron lid. Meter box shall be Carson Model #15202002 or approved equal. Meter box Lid with factory AMI antenna hole shall be Sigma LC-223T or approved equal.

3.23.3 **Water Meters** – Meters shall be furnished by the City.

3.23.4 **Service Saddle** – Service saddles shall be for installation on PVC and ductile iron pipe shall be Epoxy Coated, Iron bodied units with stainless steel banding and hardware and shall be Ford Style FC202 or approved equal.

3.23.5 **Pipe** – Service pipe shall be type K copper or PEXa. Type K copper shall be of domestic manufacturing.

**DEVELOPER SPECIFIC:** service line material shall be proposed at time of plan submission. **OWNER** shall review proposed type and confirm service line type prior to plan approval.

### 3.24 **MARKER POSTS & TRACER WIRE**

3.24.1 **Valve locations** outside the roadway and along the water line shall be marked by a TriView TracerPed Marker Post. Post shall be 90" in length with direct bury base. Post shall be Blue in color topped with a Black cap. Caps shall have white reflective decals installed on each side. Marker post shall read "Warning Water Pipeline." Post shall be equipped with internal tracer wire terminals beneath the removable cap. Cap shall be equipped with an optional Cap Lock and the City Utility shall be provided 2 keys with each installation project (i.e. 2 keys for each completed and accepted project, phase, section or subdivision). Post shall be direct bury and shall be cut to length as needed per location.

### 3.24 **MARKER POSTS & TRACER WIRE (cont)**

3.24.2 **Tracer Wire** -Tracer Wire shall be installed on ALL Non-Ductile Iron Piping. However, tracer wire shall not be directly taped to pipe but shall instead be installed three inches (3") above pipe. Tracer wire shall be constructed of a steel inner core with a copper cladding metallurgically bonded to the surface. Tracer wire shall be #12 AWG with a copper clad conductor with an O.D. of 0.0808", 0.030" HDPE insulation for an overall wire O.D. of 0.141". #12 AWG wire shall have a minimum tensile strength of 380 lbs. Wire shall be blue in color and shall either be attached directly to the pipe as it is installed, and/ or installed atop the gravel cover as directed by the resident Inspector. Tracer wire shall be as manufactured by Copperhead Industries, LLC. or pre-approved equal. If a field splice cannot be made at a locator post, a Copperhead SCB-01 for direct splices and 3WB-01 for third leg add-ons, such as services or new taps, shall be used. CONTRACTOR shall demonstrate the continuity of all tracer wire installed prior to acceptance of the project by the City Utility.

### 3.25 **FLOWABLE FILL** – All flowable mortar shall be in accordance with the Standard Specifications for Road and Bridge Construction except as modified herein.

<u>MATERIAL</u>	<u>SUBSECTION</u>
Portland Cement, Type I	901.01
Fly Ash, Class C or Class F	AASHTO M295
Water	918.01
Chemical Additives	918.09

Fine aggregate shall conform to the requirements Subsection 903.01. Fine aggregate for concrete except that the gradation shall be as follows:

<u>SIEVE SIZE</u>	<u>PERCENT PASSING</u>
¾ - inch	100
No. 200	0-10

Flowable fill mortar shall be proportioned as follows:

<u>MATERIAL</u>	<u>PER CUBIC YARD</u>
Portland Cement, Type I	100 lbs. (Maximum)
Fly Ash, Class C or Class F	250 lbs. (Minimum)
Fine Aggregate	2800 lbs.
Water	60 gal (Approximate)

The above proportions may be adjusted by the **ENGINEER** to obtain the consistency required for satisfactory flow. Consistency shall be determined as follows:

Place an open-ended cylinder (pipe) three inches in diameter by six inches in height in an upright position on a smooth, level surface. Fill the cylinder with a representative sample of the flowable fill mortar proposed for use. Remove the cylinder by lifting it straight up thus allowing the sample to diffuse on the smooth, level surface. The flowable fill mortar should diffuse into a circular shape having an approximate diameter of not less than eight inches.

**SECTION 4 - EXCAVATION & BACKFILL**

- 4.01 **GENERAL** - The **CONTRACTOR** shall perform all required excavation and backfilling incidental to the installation of water mains and other appurtenances under this contract. Excavation shall be carried to the depths indicated on the drawings or as necessary to permit the installation of pipe, bedding, structures or appurtenances. Care shall be taken to provide a firm, undisturbed, uniform surface in the bottoms of trenches and excavations for structures. Where the excavation exceeds the required depth, the **CONTRACTOR** shall bring the excavation to proper grade through the use of an approved incompressible backfill material (generally crushed stone or fill concrete, depending upon the nature of the facility to be placed thereon). In the event unstable soil conditions are encountered at the bottom of the excavation, the **INSPECTOR** may direct the **CONTRACTOR** to continue the excavation to firm soil or to provide pilings or other suitable special foundations.

The **CONTRACTOR** shall take such precautions as may be necessary to avoid endangering personnel, pavement, adjacent utilities or structures through cave-ins, slides, settlement or other soil disturbance resulting from his operations.

Backfilling shall be carried out as expeditiously as possible, but shall not be undertaken until the **INSPECTOR** has been given the opportunity to inspect the work. The **CONTRACTOR** must carry out all backfilling operations with due regard for: the protection of pipes, structures and appurtenances; the use of prescribed backfill materials; and procedures to obtain the desired degree of compaction.

The **CONTRACTOR** shall be responsible for storage of excavated material, disposal of surplus excavated material, trench dewatering and other operations incidental to excavation and backfilling operations.

- 4.02 **CLASSIFICATION OF EXCAVATION** - Excavation shall be unclassified on this project.

- 4.03 **TRENCH EXCAVATION** - Trenches shall be neatly excavated to the alignment and depth required for the proper installation of pipe, bedding material and appurtenances. Trenches shall be opened up far enough ahead of pipe laying to reveal obstructions, but in general shall not include more than 300 feet of continuous open trench at any time. The **CONTRACTOR** will be required to follow up trenching operations promptly with pipe laying, backfill and clean-up, and in event of failure to do so, may be prohibited from opening additional trench until such work is completed.

The **CONTRACTOR** shall plan his operations so as to cause a minimum of inconvenience to property owners and to traffic. No road, street or alley may be closed unless absolutely necessary and then only if the following conditions are met:

1. Permit is secured from appropriate State, County or Municipal authorities having jurisdiction.
2. Fire and Police Departments are notified before road is closed.
3. Suitable detours are provided and are clearly marked.

No driveways shall be cut or blocked without first notifying the occupant of the property. Every effort shall be made to schedule the blocking of drives to suit the occupants' convenience, and except in case of emergency, drives shall not be blocked for a period of more than eight (8) hours.

#### 4.03 **TRENCH EXCAVATION** (continued)

The **CONTRACTOR** shall furnish and maintain barricades, signs, flashing lights, and other warning devices as necessary for the protection of public safety. Flagmen shall be provided as required on heavily traveled streets to avoid traffic jams or accidents.

Trench width shall be held to a minimum consistent with proper working space for assembly of pipe. Minimum trench width shall be diameter of pipe plus twenty inches (20"). Maximum trench width up to a point one foot above top of pipe shall be limited to the outside pipe diameter plus thirty inches (30"). Boulders, large stone, shale and rock shall be removed to provide clearance of six inches (6") below the pipe and replaced with crushed stone.

Trench walls shall be kept as nearly vertical as possible with due consideration to soil conditions encountered and when necessary, sheeting or bracing shall be provided to protect life and property.

Where unstable soil conditions are encountered at the trench bottom, the **CONTRACTOR** shall remove such additional material as may be directed by the **INSPECTOR** and replace the excavated material with crushed stone.

The **CONTRACTOR** shall excavate by hand wherever necessary to protect existing structures or utilities from damage or to prevent over-depth excavation in the trench subgrade. Excavated material shall be stored safely away from the edge of trench and in such a way as to avoid encroachment on private property.

The trench shall be excavated to sufficient depth to permit a minimum cover as indicated on drawings. The bottom of the trenches must be shaped by hand and bell holes must be dug so that the full length of pipe is resting on trench bottom. Blocking shall not be used and neither shall the pipe be laid on a trench bottom that has not been leveled to provide support throughout the full length of the pipe.

The **CONTRACTOR'S** attention is called to the fact that the thirty-six inches (36") depth of cover shown on plans is a minimum and may be exceeded in instances where obstructions are encountered in trenching operations as show on plans. The **CONTRACTOR** will be permitted to lay the water pipe above the obstruction only if the minimum cover required can be obtained while providing a cushion at least six (6") thick between the bottom of the pipe and the top of the obstruction. Where this minimum cover and the required clearance cannot be obtained the **CONTRACTOR** will be required to lay the pipe under the obstruction and will receive no additional compensation for the additional depth of trench required for constructing the line in this manner. The **CONTRACTOR** will also be required to gradually increase the depth of trench when approaching cuts, creek banks, or other changes in grade in order to avoid the use of fittings, wherever it is practical to do so.

#### 4.04 **EXCAVATION FOR STRUCTURES** - Excavation for structure shall be only as large as may be required for the structure and for working room around the structure. In earth, excavation shall generally extend to the outer limits of the structure at the bottom, and shall slope outward at such angle as may be required for stability of excavated face. In rock, excavation shall be carried to a point six inches (6") outside the structure so that no rock is left within six inches (6") of the finished structure.

#### 4.04 **EXCAVATION FOR STRUCTURES** (continued)

Care shall be taken as the excavation approaches the desired grade to avoid over-depth excavation and provide a firm and undisturbed soil surface on which footings, slabs or foundations are to be placed. Should the **CONTRACTOR** excavate below the desired grade level, the excavation shall be brought to grade by the use of concrete or compacted crushed stone at the expense of the **CONTRACTOR**. The use of tamped earth backfill under foundations, footings or slabs will not be acceptable.

Where structures rest partially or wholly upon rock, the rock shall be excavated to a point six inches (6") below bottom of structure and compacted crushed stone shall be used to bring the excavation back to grade, provided however, that where the structure will rest completely on sound solid rock, the **ENGINEER** may at his discretion permit the footing, foundation or slab to be placed directly upon the rock surface.

Where the **CONTRACTOR** is permitted to place concrete directly on the rock, all dirt and weathered rock shall be removed and any seams or crevices shall be cleaned and filled with grout or mortar prior to placement of the structural concrete.

Should the material found at the desired subgrade appear to be unstable or otherwise unsuitable for support of the structure, such condition shall be immediately called to the attention of the **ENGINEER**. The **ENGINEER** may direct that such unsuitable material be removed and replaced with compacted crushed stone.

The **ENGINEER** may modify the foundation design to suit the condition, or he may determine that the bearing capacity of the material is suitable for the load to be supported; but in any case he shall provide written instructions to the **CONTRACTOR** as to the procedure to be followed.

#### 4.05 **ROCK EXCAVATION** - Rock excavation shall consist of loosening, removing and disposing of all rock larger than 9 cu. ft. in volume, which in the opinion of the **ENGINEERS** can only be removed by blasting or other equivalent methods. Such materials to be classified as solid rock shall include boulders, bedrock, or solid concrete but shall not include pavement or shoaly materials that can be loosened by other methods.

Where rock excavation is encountered in trenches the excavation shall be carried to a depth of six inches (6") below the bottom of the pipe. The rock shall also be removed to a width of at least the minimum trench width as delineated in Section 4.03 "**Trench Excavation**". Where rock is excavated in the bottom of the trench, the trench shall be brought back to grade by the use of **crushed stone**.

The **CONTRACTOR** shall exercise all necessary precautions in blasting operations. Suitable blasting mats shall be provided and utilized as required. Blasting shall be done only by experienced personnel. Careless shooting, resulting in the ejection of stones or other debris during blasting, shall be corrected immediately by the **CONTRACTOR'S** representative.

No blasting shall be done unless the **CONTRACTOR** shall have taken out the necessary insurance to fully protect the **CITY OF GALLATIN** from all possible damages resulting from the blasting operations. The blasting shall be done in accordance with all recognized safety precautions and in accordance with regulations of authorities having jurisdiction. In addition, the **CONTRACTOR** shall exercise the necessary care to safeguard and adequately protect stored blasting materials.

**4.05 ROCK EXCAVATION** (continued)

Where rock is encountered in the immediate vicinity of gas mains, telephone cables, building footings, gasoline tanks, or other hazardous areas the **CONTRACTOR** shall remove the rock by means other than blasting. Care shall be taken in blasting operations to see that pipe or other structures previously installed are not damaged by blasting. In general, blasting shall not be done within twenty-five feet (25') of the complete pipeline.

Excavated rock that cannot be utilized in trench backfill as permitted under Section 4.09 shall be removed from the site and disposed of as directed by the **ENGINEERS**.

**4.06 REMOVAL OF WATER** - The **CONTRACTOR** shall be responsible for handling run-off, and ground water in such a way as to maintain trenches and excavations in a dry condition until the work is completed. Pumps, piping, well points, labor, fuel, and other facilities necessary to control, intercept, remove and/or dispose of water shall be provided by the **CONTRACTOR** at his own expense.

Water shall be kept out of trenches and other excavations to the extent necessary to protect the supporting strength of the foundation material, permit efficient, and satisfactory assembly or replacement of facilities, and to prevent floating or misalignment. Water removed from trenches or holes shall be discharged to natural drains in such a way as to avoid danger or damage to adjacent property owners or sewers.

Where the **CONTRACTOR** fails, refuses, or neglects to control water in trenches or other excavations, and corrective work is deemed by the **ENGINEER** to be necessary as a consequence thereof, such work shall be at the **CONTRACTOR'S** expense.

**4.07 STORAGE OF EXCAVATED MATERIAL** - Excavated material shall be deposited in such a manner as to avoid danger to workmen, water line, or traffic, and to cause minimum inconvenience through blocking of drives, sidewalks, natural drains, etc. Where indicated on the drawings, or necessitated by conditions prevailing, the **CONTRACTOR** shall haul away and stockpile excavated material.**4.08 DISPOSAL OF SURPLUS EXCAVATED MATERIAL** - Excavated material that is unsuitable or unnecessary for backfilling shall be removed from the job site and disposed of at the **CONTRACTOR'S** expense. The **CONTRACTOR** must not sell or give away surplus excavated material suitable for backfilling or surfacing until the excavation has been refilled and surfaced. **CONTRACTOR** shall have the approval of each property **OWNER** and the **CITY OF GALLATIN** prior to the removal of excess material. The **CONTRACTOR** shall make his own arrangements for disposal.**4.09 BACKFILL FOR TRENCHES**

A. **General** - Backfilling of trenches will proceed as pipe laying progresses so that the trench will be filled in as rapidly as possible after the pipe has been assembled and inspected. The **CONTRACTOR** shall, however, afford the inspector ample opportunity for observing the assembled pipeline before placing the backfill and, if requested by the inspector shall delay the backfilling operation when the inspector is not present at the site.

Backfilling procedures will normally fall under three categories as follows:

1. Under streets and highways with permanent type pavement (hotmix, concrete, etc.).

4.09 **BACKFILL FOR TRENCHES** (continued)

2. In areas subject to light or occasional traffic, either under temporary paving such as surface treatment or in unpaved areas (this category will include shoulders, and driveways, except where permanent type pavement is used).
3. Open field or other areas not covered under Item 1 or Item 2 above.

B. **Backfill for water main trenches** - Backfill under streets, or highways having permanent type pavement as indicated in category one shall consist of crushed stone suitably compacted for the entire trench depth. The crushed stone shall be carefully placed by hand around and under the pipe in layers not to exceed twelve inches (12") in depth and shall be compacted by means of hand tamps or other approved tamping procedure. The crushed stone backfill shall be placed by approved method up to a point twelve inches (12") above the top of the pipe and above this point may be placed by mechanical equipment. In any event the backfill shall be placed in layers not exceeding nine inches (9") and shall then be compacted by suitable mechanical means.

Flowable fill mortar shall be placed in locations shown on the Plans or as direct by the **ENGINEER**. The flowable fill mortar shall be covered by necessary means i.e., steel plans or any other approved means while in the plastic state. Backfill shall not be placed on the flowable fill mortar prior to final set or hardening as determined by the **ENGINEER**. Flowable fill mortar shall at no time come in direct contact with any utility lines. Flowable fill mortar shall commence six inches above top of pipe. Placement shall be in accordance with TDOT Standards for Road and Bridge Construction.

For categories two and three, the pipe bedding below shall be twelve inches (12") below and twelve inches (12") above the top of the **pipe shall be crushed stone**. When the backfill has been placed to a depth at least twelve inches (12") above the top of the pipe, the remainder of the backfill in category two (areas subject to light traffic) shall consist of suitable excavated material placed and compacted in layers not exceeding twelve inches (12") in depth. **No rock larger than six inches (6") in any dimension may be included within the backfill. The compaction shall be obtained by means of a suitable mechanical tamper.**

Should the **CONTRACTOR** fail, refuse or neglect to systematically exclude or remove oversize rock from the backfill material, he may be required to place and compact the backfill material by other suitable methods, which will insure the rocks being removed.

The backfill for areas not ordinarily subjected to traffic, may consist of suitable excavated material placed by machine after the crushed stone backfill reaches a depth of twelve inches (12") over the top of the pipe, and the backfill shall be compacted by means of a suitable wheeled vehicle such as a tractor or front end loader running longitudinally along the trench. After the backfill has been compacted in this manner additional fill material shall be placed in the trench to restore the original grade and provide a slight mound over the trench. This material shall again be compacted by means of a suitable wheeled vehicle. **No rock larger than six inches (6") in any dimension may be used in the backfill over the pipe and no rock larger than one half inch (1/2") may be used in the top six inches (6") of the backfill.**

**4.09 BACKFILL FOR TRENCHES** (continued)

Backfill up to the spring line of the pipe shall be placed as pipe laying progresses in order to maintain proper grade and alignment. Additional backfill shall not be placed until after the pipe has been inspected by the **ENGINEERS** and approved for backfill.

**4.10 ACCEPTABLE BACKFILL MATERIAL** - Where crushed stone backfill is required the crushed stone shall be No. 67 size as designated by Tennessee Department of Transportation Specifications and shall meet all requirements of the TDOT Specifications for crushed stone used in road surfacing.

Where crushed stone is not required, but the excavated material is unsuitable for use in the backfill, the **CONTRACTOR** may use fine dry selected earth or clay as backfill material. **Material containing excessive organic matter, stumps, roots, refuse or foreign matter or hard clay lumps that cannot readily be compacted will not be acceptable for use as backfill.**

**SECTION 5 - PAVEMENT REPLACEMENT**

- 5.01 **GENERAL** - The **CONTRACTOR** shall be responsible for replacement of pavement removed or damaged by his operations. Pavement replacement shall be in accordance with this section of the specifications and in every case shall be equal to or better than the quality of pavement damaged or removed. The **CONTRACTOR** shall also be responsible for subsequent pavement failures during the warranty period, where such failures occur over or adjacent to trenches or other excavations by the **CONTRACTOR** and result from insufficient compaction of the backfill.
- 5.02 **PAVEMENT REMOVAL** - Where existing paved streets, roads, parking lots, drives or sidewalks must be disturbed during construction of the project the **CONTRACTOR** shall take the necessary steps to minimize damage. Permanent type pavement shall be cut or sawed in a straight line before removal and care shall be taken during excavation to avoid damage to adjacent pavement. Where trucks or other heavy equipment must cross curbs or sidewalks, such areas shall be suitably protected.
- 5.03 **PAVEMENT REPLACEMENT** - Before trenching in paved areas the **CONTRACTOR** shall cut through the pavement in a straight line along the sides of the proposed trench so that the pavement may be removed and the trench may be dug without damage to the adjacent pavement. During construction suitable precautions shall be taken to protect the pavement edges and surfaces and minimize damage.

As soon as the pipe has been installed the trench shall be backfilled as specified in Section 4.09 and a temporary pavement patch shall be provided in paved areas. The temporary pavement shall consist of a single or double surface treatment, which will protect the base, prevent "pot holes" or "chuck holes" and provide a reasonable smooth pavement surface until the permanent patch is made.

The permanent pavement patch shall not be made until the job is nearing completion in order to allow maximum time for any further settlement. The permanent pavement patch shall conform to the following schedule:

1. **Principal highways, including traffic lanes, and turn lanes** - minimum of two feet (2') of flowable fill within the pip ditch, four inches (4") of binder and two inches (2") of hot mix asphalt Grade E.
2. **City primary and secondary Streets** – minimum of two feet (2') of flowable fill within the pip ditch and two inches (2") of hot mix asphalt Grade E. See detail in plan set.
3. **Paved parking areas, paved shoulders, turnouts and driveways with bituminous concrete or equivalent surfacing** - two inches (2") of TDOT 411 "E" mix extending two feet (2') each side of trench wall and over eight inches (8") of crushed stone base.
4. **Parking areas, shoulders, turnouts and driveways with surface treatment or equivalent pavement** -double surface treatment over eight inches (8") crushed stone base. Replacement shall be of equal to the original.
5. **Concrete driveways, sidewalks, curbs and gutters, etc.** -Class A concrete of thickness equivalent to original construction.

5.03 **PAVEMENT REPLACEMENT** (continued)

6. **County roads** - Two inches (2") of TDOT 411 "E" Mix topping over eight inches (8") of TDOT 307 "B" modified binder in accordance with County Road requirements.

The hot mix and surface treatment applications shall be in accordance with standard specifications and recommended practices of the Tennessee Department of Transportation.

Pavement replacement shall extend a minimum of one foot (1') beyond the trench line and shall include replacement of all defective pavement resulting from the **CONTRACTOR'S** operations, regardless of whether caused by blasting, trenching, equipment operation, cave-in or other cause. Where the cut edge of pavement is less than one foot (1') from the edge of the trench or has been disturbed during construction, the **CONTRACTOR** shall cut through and remove existing pavement as required to permit a neat pavement patch. Irregular or uneven patches will not be permitted.

The **CONTRACTOR** shall be responsible for maintaining temporary patches during construction and shall promptly repair any defects. Upon completion of the work the paved surfaces shall be left in as good or better condition than before the start of construction.

The **CONTRACTOR** shall obtain a road cut permit and contract from the Highway Department for each crossing if required by controlling authority. The **CONTRACTOR** shall conform to all conditions of said permit and bear all costs associated with said permit.

**SECTION 6 - INSTALLATION OF WATER PIPE AND ACCESSORIES**

- 6.01 **GENERAL** - Water pipe shall be furnished and installed in accordance with details shown on the drawings. The work shall be done by experienced workmen employed by a general contractor licensed in the State of Tennessee with the appropriate classification. Pipe, fittings, valves and accessories shall be installed in strict accordance with these specifications and the recommendations of the manufacturer. Gaskets, bolts, lubricant and other accessories shall be furnished by or as recommended by the manufacturer.

The **CONTRACTOR** shall use top quality materials throughout and shall exercise care in the storage, handling and installation of the pipe and accessories. Trench bottoms must be carefully graded by hand to provide continuous support for the pipe except at bells where bell holes must be dug.

- 6.02 **HANDLING PIPE AND ACCESSORIES** - All water pipe, fittings, valves and other appurtenances shall be stored in a protected location where they will not be subject to physical damage or contamination. Pipe may be delivered to the trench site only if it is unloaded with suitable mechanical equipment and left in an area where it will not be a hazard or obstruction and will not be subject to flooding. Pipe, fittings, valves, hydrants shall not be rolled or dropped from trucks or trailers and shall not be left in roadside ditches.

Pipe clamps, slings, hooks, hoists, booms or other equipment as required for safe and efficient handling of pipe and accessories shall be provided at the trench site whenever pipe laying is in progress.

A suitable swab or brush shall be provided and shall be run through each and every joint of pipe to insure the removal of dirt and foreign objects. The pipe shall be inspected for defects immediately before being lowered into the ditch.

All stored pipe shall have adequate end protection installed to prevent contamination of the pipe during storage. End protection shall remain in place until the pipe is ready for installation. Any damaged or missing end protection shall be replaced promptly. Pipe shall not be without end protection for more than 5 days or **OWNER/ENGINEER** may stop laying operations until protection is installed.

- 6.03 **INSTALLATION OF DUCTILE IRON PIPE** - Ductile iron pipe shall be installed in accordance with AWWA Standard C600 and the manufacturer's recommendations using Laying Condition Type 2.

After the pipe has been swabbed and inspected it shall be lowered into the trench. The spigot end of the pipe and the bell or socket of the previously laid pipe shall be wiped clean. The gasket shall be inserted, lubricant shall be applied and the joint shall be made up by shoving the pipe home. Care shall be taken to insure that the gasket is not twisted or dislodged and that the pipe spigot is inserted the proper distance into the socket. When making up mechanical joints the bolt shall all be tightened to the proper torque at the time the joint is made up to ensure proper torque and even spacing between the gland and the face of the flange at all points by partially tightening and alternating between top and bottom bolts in a stepwise manner.

Suitable wheel or squeeze cutters or a power saw shall be used for cutting gray iron pipe but squeeze cutters shall not be used on ductile iron.

**6.03 INSTALLATION OF DUCTILE IRON PIPE** (continued)

Pipe shall be cut neat and true with cut being made perpendicular to pipe axis.

A coarse file or power grinder shall be used to smooth the face of the cut and bevel the outside edge to prevent damage to the gasket.

Fittings and valves shall be installed in the line as shown on the drawings and as directed by the **ENGINEER**. Valves shall be installed in a horizontal run of pipe with valve stem in a vertical position. Buried valves shall have a two inch (2") square operating nut and extension stems shall be provided as required to bring the operating nut to within thirty inches (30") of the finished ground surface.

Pipes shall be laid to a reasonably uniform grade without kinks or other irregularities. Curves or changes in grade will be laid by making deflections at the pipe joints where feasible but the maximum permissible deflections shall be as shown in published tables of the Ductile Iron Pipe Research Association.

All pipe shall have a metallic tape or similar device installed not more than 18" above the pipe and in accordance with manufacturer's recommendation. The metallic device shall be Terra Tape or approved equal and shall be compatible with City location equipment.

**6.04 INSTALLATION OF POLYVINYL CHLORIDE (PVC) PIPE** - PVC pipe shall be installed in strict accordance with manufacturer's recommendations. Fittings and valves shall be installed as described for Ductile Iron and in accordance with manufacturer's recommendations.

All pipe shall have tracer wire (see Section 3.22) installed onto or near the pipe and a metallic tape or similar device installed not more than 18" above the pipe and in accordance with manufacturer's recommendation. The metallic device shall be Terra Tape or approved equal and shall be compatible with City location equipment.

**6.05 INSTALLATION OF HDPE PIPE** – HDPE pipe shall be installed in strict accordance with manufacturer's recommendations. Fittings and valves shall be installed as described for Ductile Iron and in accordance with manufacturer's recommendations.

All pipe shall have tracer wire (see Section 3.22) installed onto or near the pipe and a metallic tape or similar device installed not more than 18" above the pipe and in accordance with manufacturer's recommendation. The metallic device shall be Terra Tape or approved equal and shall be compatible with City location equipment.

HDPE may be installed without fittings where slight bends are necessary. The minimum bend radius for DR-11 HDPE shall be 30 times the pipe diameter. Pipe installations which cannot provide the necessary radius must be installed using the appropriate fittings.

- 6.06 **INSTALLING FIRE HYDRANTS** - Fire hydrants shall be located as shown on the Plans and as directed by the **ENGINEER**. The hydrant shall be set in a vertical position at the edge of the street right-of-way with the pumper nozzle facing the street.

Installation of the fire Hydrant Isolation valve shall be made by use of a Foster adapter or a Hydrant locking TEE. Installation of the fire hydrant to the valve shall be via a similar restraint device. If standard pipe is used, a Megalug or similar restraint shall be used on each end of the connecting pipe section.

The hydrant shall be set on a poured in place concrete pad, which shall also serve as a kicker against the undisturbed trench face.

The concrete shall have horizontal and vertical bearing areas of at least 3 square feet against the undisturbed trench bottom and side respectively, but shall not cover the flanges or drain ports. At least 7 cu. ft. of crushed stone shall be provided around the hydrant for drainage.

Hydrants shall be set so that the finished ground level will be just below the breakable flange or at the bury level indicated on the hydrant.

The lower barrel of the hydrant shall be of sufficient length to enable the hydrant head to be installed horizontally even though the hydrant may be located in an embankment.

Installed hydrants shall have an undamaged enamel coating and oil reservoirs shall be filled.

- 6.07 **THRUST BLOCKS AND RESTRAINTS** - Poured in place concrete thrust blocks must be provided at all points of unbalanced pressure where the pipeline could pull apart. Thrust blocks shall conform to details and minimum bearing areas as shown on the drawings and shall bear against the undisturbed trench face. Contractors may elect to use an approved type of locked flexible joint extending on each side of bend as per standard drawings.

All fittings, valves and hydrants shall be installed with mechanical restraint joints. Ductile iron pipe shall be EBAA Iron Sales, Inc. Series 1100, Tyler Union TUF Grip or approved equal, and PVC restraints shall be EBAA Iron Sales, Inc. Series 2000 PV, Tyler Union TUF Grip or approved equal.

Where over bends (downward bends) cannot be avoided the fitting must be held in place by one of the following methods:

1. Poured concrete under pipe of sufficient volume to counteract unbalanced force with steel clamp and anchor bolts to hold fitting to concrete as per standard drawings.
2. Approved type of locked flexible joint extending on each side of bend as per standard drawings.

6.08 **VALVE BOX INSTALLATIONS** - Valve boxes shall be centered over the valve-operating nut and installed in a vertical position. Box shall be of the proper length to extend to the ground surface and allow the adjustable upper section to be positioned approximately midway between upper and lower limits. Backfill shall be carefully tamped around valve box and suitable support shall be provided under and around the upper section to prevent future settlement. Valve boxes shall be installed in such a manner that the long dimension of the box is in-line with the laying direction of the pipe that the valve is installed on.

6.09 **CONNECTIONS TO EXISTING MAINS** - The **CONTRACTOR** shall make connections to existing mains as shown on the drawings or described herein. Connections to existing mains presently in service shall be made with tapping sleeves and valves without taking the existing main out of service.

The **CONTRACTOR** shall make his own arrangements for use of a tapping machine.

Where connections are to be made to pipe previously installed but not placed in service, the **CONTRACTOR** shall remove existing plugs and make the tie in by use of mechanical joint sleeves. Plugs removed from existing mains shall remain the property of the **CITY OF GALLATIN** and shall be protected from damage or loss until they are turned over to the designated representative of the **CITY OF GALLATIN**.

Where existing mains must be valved off to make connections, the **CONTRACTOR** shall notify the Water Department not less than twenty-four (24) hours prior to the making of the connection and the actual time of the service interruption shall be subject to approval by the **CITY OF GALLATIN**.

It shall be the responsibility of the **CONTRACTOR** to measure outside diameters of existing pipes before ordering tapping sleeves, or other fittings intended for connecting to existing mains.

6.10 **SERVICES AND SERVICE RELOCATIONS** - Services shall be installed as indicated on drawings and at locations as directed by **ENGINEER**. The **CONTRACTOR** shall furnish and install 2" PVC casing pipe for service line that cross under streets. PVC casings shall be installed before road base stone is applied and excavation for casing shall be backfilled with crushed stone to the full depth. Care shall be taken to maintain minimum cover over service line, including ditch line crossings as shown on drawings. All service line casing crossings of paved roads shall be installed by boring and jacking. The cost of the 2" PVC casing pipe and the boring of the casing pipe shall be included in the cost of the service pipe

6.11 **PROTECTION OF PIPE** - Whenever pipe laying operations are suspended for any reason, including lunch hour or temporary interruptions, a test plug shall be inserted in the open ends of the pipe. Temporary interruptions may include but not limited to, a ditch geometry that requires extended periods between joint installations. Proper protections shall be used, plywood or other temporary blocking methods are not to be substitution for a pipe plug sized for the pipe being laid.

The installed pipe shall be adequately protected at all times against the entrance of dirt, animals, mud, sewage or other foreign material. Pipe shall not be laid in a ditch containing standing water.

- 6.12 **INSTALLATION OF PIPE AT SEWER CROSSING** – When installing water main perpendicular to a sanitary sewer main, a minimum of eighteen inches (18”) of vertical clearance shall be between the water main and the sewer main. If the vertical clearance that can be obtained is less than eighteen inches (18”), the **CONTRACTOR** shall use one of the following options:
- The sanitary sewer main or water main shall be encased to a distance of ten feet (10') on each side of the crossing, for a total of twenty feet (20') of casing.
  - The section of sewer main crossing the water main shall be constructed of ductile iron and tested to and withstand 200 psi of pressure for one hour.
- 6.13 **INSTALLATION OF FLUSHING POINTS** – When installing a new water main, a minimum of one (1) two inch (2”) flushing point shall be provided at the end of all newly installed mains for flushing purposes. Type of flush point shall be determined by the owner.

**SECTION 7 - TESTING AND DISINFECTION - WATER MAIN**

- 7.01 **GENERAL** - Upon completion of the construction work under this contract all water lines shall be disinfected and subjected to the necessary pressure and leakage tests. In the event the pressure or leakage test is unsatisfactory, or bacteriological tests indicate that disinfection is incomplete, corrective measures shall be taken and the tests repeated until satisfactory results are obtained.

- 7.02 **PRESSURE AND LEAKAGE TESTS** - All water lines shall be subjected to a hydrostatic pressure of 200 psi for a period of two hours, and any defective work revealed by the test shall be repaired or replaced by the **CONTRACTOR**.

The allowable water loss/leakage for this one (1) hour period is not to exceed (0) zero gallons. Should the amount of leakage exceed the "Zero Loss" limit, the **CONTRACTOR** shall locate and repair the defective joints until the leakage is within the specified limits.

In no event shall the leakage exceed the allowable leakage for mechanical or push on joints as shown in Table 6 of the AWWA C600-87 Standard.

The **CONTRACTOR** shall provide all labor, tools, equipment and materials for making the tests.

**CONTRACTOR** should note that 200 psi test pressure is required although some large Butterfly Valves are bottle tight only to 150 psi across the valve. Attention should be given that at least 50 psi system pressure be on the low side or that valve be installed such that direction of pressure is on that face of the valve closure that provides the highest bottle tight pressure.

- 7.03 **DISINFECTION** - All water lines, including pipe, valves, meters, etc., shall be disinfected prior to being placed in service in accordance with AWWA C651-05, after the system has been flushed to remove dirt or foreign objects which may have been accidentally introduced into the line.

For this work, the **CONTRACTOR** shall furnish suitable plugs or caps for the pipe, injection pumps, pipe connections, chlorine and other equipment with all labor required.

While the disinfectant is being applied to any section of the system, the water shall be allowed to escape all extremities of this section. The method of chlorine residual testing shall be the DPD color comparator method. The disinfectant residual shall be raised to a minimum of 25 mg/L and shall be allowed to remain in the pipe for 24 hours, after which the lines shall be thoroughly flushed until only the residual chlorine found in tap water is present (typically a residual between 1.0 and 2.5 is considered adequately flushed), and at this time bacteriological samples shall be called for.

Samples of water shall then be taken by **CITY** personnel and shall be submitted to the bacteriological laboratory at the **CITY'S** water plant laboratory. In the event any of the bacteriological samples show the presence of coliform organisms or an excessive total count, the disinfection procedure shall be repeated until samples of satisfactory quality can be obtained.

Upon completion of successful disinfection, **CONTRACTOR** shall furnish the City with a "Letter of Chlorination" which will include the method of disinfection used, the amount and type of disinfectant used. See example letter in Appendix A

7.04 **FLUSHING** – All new water mains shall be flushed from the provided flush point. Flushing shall be as directed by the owner of sufficient velocity to properly scour the newly installed pipe, and shall be of the volume necessary to adequately remove and test water from the system.

7.05 **TESTING AND DISINFECTION PROCEDURE**

New water mains shall follow the procedure for flushing and testing prior to acceptance.

- Main shall be disinfected using the appropriate amount of HTH, bleach or other disinfectant.
- Once the new main has exhibited the appropriate disinfection required based on size of main and time, the main shall be thoroughly flushed. All flushed water must be neutralized as necessary to ensure no highly chlorinated water is discharged to the surrounding receiving streams.
- Once properly flushed, Bac-T sampling shall be completed. Number of samples required shall be based on length of main installed or per the OWNER.
- Upon receipt of a passing Bac-T sample, the main may be prepared for pressure testing. If a failing sample is received, the process must be started over, including re-disinfection, flushing and the pulling of additional samples. This process shall be repeated until all samples pass
- Upon receipt of passing Bac-T samples the new main shall be pressure tested per section 7.02
- Upon passing the pressure test the new main shall be allowed to be placed into service.
- OWNER reserves the right to modify or adjust this procedure as may be required to ensure the safety of the public water system.

**SECTION 8 - SPECIAL CONDITIONS**

- 8.01 **GENERAL** - The **CONTRACTORS** attention is called to the special conditions indicated on the plans and described in this section of the specifications. Special conditions include construction on highway or railroad right-of-way, construction in the vicinity of existing utilities, and special surface restoration.
- 8.02 **WORK ON HIGHWAY RIGHT-OF-WAY** - The **CONTRACTOR** shall be responsible for complying with the requirements of the appropriate Highway Department. In the event a surety bond is required, such bond will be provided by the **CONTRACTOR**.
- 8.03 **WORK ON RAILROAD RIGHT-OF-WAY** - Should it be necessary to do any excavating or trenching on railroad rights-of-ways, the **CONTRACTOR** shall notify the railroad and shall conform to their requirements when performing work on their rights-of-way.
- 8.04 **COORDINATION WITH OTHER UTILITIES** - The **CONTRACTOR** shall cooperate with other utilities and shall take every reasonable precaution to avoid conflicts. In instances where the proposed water lines will be located near existing or proposed utility lines, the **CONTRACTOR** shall take the necessary steps to avoid damage to the utility lines and shall notify the **CITY** of any potentially hazardous situations.
- 8.05 **SEEDING** - In all areas damaged or disturbed by **CONTRACTOR'S** operations where established ground cover was present before beginning of construction, **CONTRACTOR** shall be responsible for restoring this ground cover after completion of construction. (Unless noted otherwise on drawings). In areas of established lawns, **CONTRACTOR** will be required to: separate and preserve best of excavated material or, if no acceptable material has been excavated, haul in an acceptable material for use in making top six inches (6") of finished grade. No rock will be permitted in this top six inches (6") of finished grade for established lawns. All areas seeded shall be graded smooth prior to seeding and **CONTRACTOR** shall be responsible for maintenance of this smooth finished grade until grass growth is established.

After designated areas have been carefully hand graded, soil shall be prepared for seeding. Where necessary, **CONTRACTOR** will sod slopes and embankments, and remaining areas may be seeded.

A well-made lawn is desired, and **CONTRACTOR** will be responsible for any necessary regrading or reseeding required to produce an acceptable grass as cover. The seed is to be of the same type of grass existing before construction.

The soil shall be fertilized with a commercial fertilizer of a grade and at a rate recommended by vendor of seed.

All seeded areas shall be covered with clean straw uniformly distributed to approved density.

- 8.06 **CASING PIPE** - Is intended to be installed by bore and jack. Installation may be made by open cut only if authorized in writing by the **CITY OF GALLATIN**, and generally only after an attempted bore is unsuccessful. In no event will construction method be contradictory of instruction of the Railroad or Highway Department. In the event of any unsuccessful bore attempts, the bore hole will be refilled according to instructions of the Railroad or Highway Department or outside their jurisdiction by leaving jacked casing in place and sealing end with brick and mortar.

- 8.07 **SERVICE RELOCATIONS** - The service relocations shall consist of installing a new service line from the proposed main to the new meter setting on the existing customer service line as directed by the **CITY**. All existing service regulators or control devices on the existing customer line shall be relocated. The **CONTRACTOR** shall be responsible for lowering customer service lines to depths as necessary for proper connection. The **CONTRACTOR** shall furnish a new corporation stop, yoke and meter box at each location. All service line installation shall be installed as delineated herein.

8.08 **SLOPE PROTECTION AND EROSION CONTROL**

A. **General**

This section shall consist of temporary control measures as shown in the Plans or directed by the **ENGINEER** during the life of the Contract to control erosion and water pollution through the use of berms, dikes, dams, sediment basins, fiber mats, netting, mulches, grasses, slope drains, temporary silt fences, and other control devices.

The temporary pollution control provisions contained herein shall be coordinated with the permanent erosion control features to assure economical effective and continuous erosion control throughout the construction and post-construction period.

B. **Materials**

1. **Temporary Berms:**

A temporary berm is constructed of compacted soil, with or without a shallow ditch, at the top of fill slopes or transverse to centerline on fills. These berms are used temporarily at the top of newly constructed slopes to prevent excessive erosion until permanent controls are installed or slopes stabilized.

2. **Temporary Slope Drains**

A temporary slope drain is a facility consisting of stone gutters, fiber mats, plastic sheets, concrete or asphalt gutters, half-round pipe, metal pipe, plastic pipe, sod or other material acceptable to the **ENGINEER** that may be used to carry water down slopes to reduce erosion.

3. **Sediment Structures**

Sediment basins, ponds and traps are prepared storage areas constructed to trap and store sediment from erodible areas in order to protect properties and stream channels below the construction areas from excessive siltation.

4. **Check Dams**

- (a). Check dams are barriers composed of logs and poles, large stones or other materials placed across a natural or constructed drainway.

8.08 **SLOPE PROTECTION AND EROSION CONTROL** (continued)

- (b). Stone check dams shall not be utilized where the drainage area exceeds fifty (50) acres. Log and pole structures shall not be used where the drainage area exceeds five (5) acres.

5. **Temporary Seeding and Mulching**

Temporary seeding and mulching are measures consisting of seeding, mulching, fertilizing, and matting utilized to reduce erosion. All cut and fill slopes including waste sites and borrow pits shall be seeded when and where necessary to eliminate erosion.

6. **Brush Barriers**

- a. Brush barriers shall consist of brush, tree trimmings, shrubs, plants and other approved refuse from the clearing and grubbing operations.
- b. Brush barriers are placed on natural ground at the bottom of all slopes where the most likely erodible areas are located to restrain sedimentation particles.

7. **Baled Hay or Straw Checks**

- a. Baled hay or straw erosion checks are temporary measures to control erosion and prevent siltation. Bales shall be either hay or straw containing five (5) cubic feet or more of material.
- b. Baled hay or straw checks shall be used where the existing ground slopes toward or away from the embankment along the toe of slopes, in ditches or other areas where siltation erosion or water run-off is a problem.

8. **Temporary Silt Fences**

Silt fences are temporary measures utilizing woven wire or other approved material attached to posts with filter cloth composed of burlap, plastic filter fabric, etc., attached to the upstream side of the fence to retain the suspended silt particles in the run-off water.

C. **EXECUTION**1. **Project Review**

Prior to the pre-construction conference the **CONTRACTOR** shall meet with the **ENGINEER** and go over in detail the expected problem areas in regard to the erosion control work. Different solutions should be discussed so that the best method might be determined. It is the basic responsibility of the **CONTRACTOR** to develop an erosion control plan acceptable to the **ENGINEER**.

8.08 **SLOPE PROTECTION AND EROSION CONTROL** (continued)2. **Pre-Construction Conference**

A the pre-construction conference the **CONTRACTOR** shall submit for acceptable his schedule for accomplishment of temporary and permanent erosion control work, as are applicable for clearing and grubbing, grading, bridges and other structures at watercourses, construction and paving. He shall also submit for acceptance his proposed method of erosion control on haul roads and borrow pits and his plan for disposal of waste materials. No work shall be started until the erosion control schedules and methods of operations have been accepted by the **ENGINEER**.

3. **Construction Requirements**

- a. The **ENGINEER** has the authority to limit the surface area of erodible earth material exposed by clearing and grubbing, the surface of erodible earth material exposed by excavation, borrow and fill operations and to direct the **CONTRACTOR** to provide immediate permanent or temporary pollution control measures to prevent contamination of adjacent streams or other watercourses, lakes, ponds, or other water impoundment. Such work may involve the construction of temporary berms, dikes, dams, sediment basins, slope drains, and use of mulches, mats, seeding or other control devices or methods as necessary to control erosion. Cut and fill slopes shall be seeded and mulched as the excavation proceeds to the extent directed by the **ENGINEER**.
- b. The **CONTRACTOR** shall be required to incorporated all permanent erosion control features into the project at the earliest practicable time as outlined in his accepted schedule. Temporary pollution control measures shall not be used to correct conditions that develop during construction that were not foreseen during the design stage; that are needed prior to installation of permanent pollution control features; or that are needed temporarily to control erosion that develops during normal construction practices, but are not associated with permanent control features on the project.

3. **Construction Requirements**

- c. Where erosion is likely to be a problem, clearing and grubbing operations should be so scheduled and performed that grading operations and permanent erosion control features can follow immediately thereafter if the project conditions permit; otherwise erosion control measures may be required between successive construction stages. Under no conditions shall the surface area of erodible earth material exposed at one time by clearing and grubbing exceed 750,000 square feet without the approval of the **ENGINEER**.

8.08 **SLOPE PROTECTION AND EROSION CONTROL** (continued)

- d. The **ENGINEER** will limit the area of excavation, borrow and embankment operations in progress commensurate with the **CONTRACTOR'S** capability and progress in keeping the finish grading, mulching, seeding and other such permanent pollution control measures current in accordance with the accepted schedule. Should seasonal limitations make such coordination unrealistic, temporary erosion control measures shall be taken immediately to the extent feasible and justified.
- e. Under no conditions shall the amount of surface area or erodible earth material exposed at one time by excavation or fill within the project area exceed 750,000 square feet without prior approval by the **ENGINEER**.
- f. The **ENGINEER** may increase or decrease the amount of surface area of erodible earth material to be exposed at one time by clearing and grubbing, excavation, borrow and fill operations as determined by his analysis of project conditions.
- g. In the event of conflict between these requirements and pollution control laws, rules or regulations, or other Federal, State or Local agencies, the more restrictive laws, rules or regulations shall apply.

4. **Construction of Structures**a. **Temporary Berms**

A temporary berm shall be constructed of compacted soil with a minimum width of twenty-four inches (24") at the top and a minimum height of twelve inches (12") with or without a shallow ditch, constructed at the top of fill slopes or transverse to centerline on fills. Temporary berms shall be graded so as to drain to a compacted outlet at a slope drain. The area adjacent to the temporary berm in the vicinity of the slope drain must be properly graded to enable this inlet to function efficiently and with minimum ponding in this area.

All transverse berms required on the downstream side of a slope drain shall extend across the grade to the highest point with an approximate ten degree (10°) angle perpendicular to the centerline. The top width of these berms may be wider and the side slope flatter on transverse berms to allow equipment to pass over these berms with minimal disruptions. When practical and until final roadway elevations are approached, embankments should be constructed with a gradual slope to one side of the embankment to permit the placement of temporary berms and slope drains on only one side of the embankment.

8.08 **SLOPE PROTECTION AND EROSION CONTROL** (continued)b. **Temporary Slope Drains**

1. Temporary slope drains shall consist of stone gutters, fiber mats, plastic sheets, concrete or asphalt gutters, half-round pipe, metal pipe, plastic pipe, flexible rubber, or other materials which can be used as temporary measures to carry water accumulating in the cuts and on the fills down the slopes prior to installation of permanent facilities or growth of adequate ground cover on the slopes.
2. Fiber matting and plastic sheeting shall not be used on slopes steeper than 4:1 except for short distances of twenty feet (20') or less.
3. All temporary slope drains shall be adequately anchored to the slope to prevent disruption by the force of the water flowing in the drains. The base for temporary slope drains shall be compacted and concavely formed to channel the water or hold the slope drain in place. The inlet end shall be properly constructed to channel water into the temporary slope drain. Energy dissipators, sediment basins or other approved devices shall be constructed at the outlet end of the slope drains to reduce erosion downstream. An ideal dissipator would be dumped rock or a small sediment basin, which would slow the water as well as pick up some sediment. All temporary slope drains shall be removed when no longer necessary and the site restored to match the surroundings.

c. **Sediment Structures**

1. Sediment structures shall be utilized to control sediment at the foot of embankments where slope drains outlet; at the bottom as well as in the ditch lines atop waste sites; in the ditch lines or borrow pits. Sediment structures may be used in most drainage situations to prevent excessive siltation of pipe structures. All sediment structures shall be at least twice as long as they are wide.
2. When use of temporary sediment structures is to be discontinued, all sediment accumulation shall be removed and all excavation backfilled and properly compacted. The existing ground shall be restored to its natural or intended condition.

d. **Check Dams**

1. Check dams shall be utilized to retard stream flow and catch small sediment loads. Materials utilized to construct check dams are varied and should be clearly illustrated or explained in the **CONTRACTOR'S** erosion control plan.

8.08 **SLOPE PROTECTION AND EROSION CONTROL** (continued)

2. All check dams shall be keyed into the sides and bottom of the channel a minimum depth of two feet (2'). A design is not needed for check dams but some typical designs are shown in the standard plans.
3. Stone check dams should generally not be utilized where the drainage area exceeds fifty (50) acres. Log and pole structures should generally not be used where the drainage area exceeds five (5) acres.

e. **Temporary Seeding and Mulching**

Seeding and mulching shall be performed in accordance with Section 02828-Miscellaneous Seeding.

f. **Brush Barriers**

Brush barriers shall consist of brush, tree trimmings, shrubs, plants, and other approved refuse from the clearing and grubbing operations. The brush barriers shall be constructed approximately parallel to original ground contour. The brush barrier shall be compressed to an approximate height of three (3) to five (5) feet and approximate width of five (5) to ten (10) feet. The embankment shall not be supported by the construction of brush barriers.

g. **Bales Hay or Straw Erosion Checks**

Hay or straw erosion checks shall be embedded in the ground four to six inches (4"-6") to prevent water flowing under them. The bales shall also be anchored securely to the ground by wooden stakes driven through the bales into the ground. Bales can remain in place until they rot or be removed after they have served their purpose, as determined by the **ENGINEER**. The **CONTRACTOR** shall keep the checks in good condition by replacing broken or damaged bales immediately after damage occurs. Normal debris clean out will be considered routine maintenance.

h. **Temporary Silt Fences**

1. Temporary silt fences shall be placed on the natural ground, at the bottom of fill slopes, in ditches, or other areas where siltation is a problem. Silt fences are constructed of wire mesh fence with a covering of burlap or some other suitable material on the upper grade side of the fence and anchored into the soil.

8.08 **SLOPE PROTECTION AND EROSION CONTROL** (continued)

2. The **CONTRACTOR** shall be required to maintain the silt fence in a satisfactory condition for the duration of the project or until its removal is requested by the **ENGINEER**. The silt accumulation at the fence may be left in place and seeded, removed, etc., as directed by the **ENGINEER**. The silt fence becomes the property of the **CONTRACTOR** whenever the fence is removed.

D. **MAINTENANCE**

- a. The temporary erosion control features installed by the **CONTRACTOR** shall be acceptably maintained by the **CONTRACTOR** until no longer needed or permanent erosion control methods are installed. Any materials removed shall become the property of the **CONTRACTOR**.
- b. In the event that temporary erosion and pollution control measures are required due to the **CONTRACTOR'S** negligence, carelessness or failure to install permanent controls as a part of work as scheduled, and are ordered by the **ENGINEER**, such work shall be performed by the **CONTRACTOR** at his own expense.
- c. Where the work to be performed is not attributed to the **CONTRACTOR'S** negligence, carelessness, or failure to install permanent controls and falls within the specifications for a work item that has a contract price, the units of work shall be paid for at the proper contract prices.

E. **EROSION CONTROL OUTSIDE PROJECT AREA**

Temporary pollution control shall include construction work outside the project area where such work is necessary as a result of construction such as borrow pit operations, haul roads and equipment storage sites. Bid price in such cases shall include all necessary clearing and grubbing, construction incidentals, maintenance and site restoration when no longer needed.

F. **MEASUREMENT AND PAYMENT**

No separate Measurement and Payment will be made for this work. It will be considered a subsidiary obligation of the **CONTRACTOR** under other bid items to which it relates.

- 8.09 **VIDEO** - Prior to construction, **CONTRACTOR** shall color video tape the entire project including the route of the line construction, all easement areas, the full width of all rights-of ways, and all service line areas. The **CONTRACTOR** shall identify the line designation and station number, all natural land marks, the street address of the area in view and all potential areas, structures, fences, trees, etc., subject to potential disturbance. The **CONTRACTOR** shall provide the **OWNER** with two (2) copies of the video with audio comments.

**SECTION 9 - WARRANTY AND MAINTENANCE OBLIGATIONS**

- 9.01 **WARRANTY** - The work to be performed under this contract shall be guaranteed against defects in materials or workmanship for a period of one year following the date of formal acceptance of the project. In the event defects in materials or workmanship should appear, the **CONTRACTOR** shall promptly make the necessary corrections. When the defects are not of an emergency nature, the **CONTRACTOR** will be notified and will be given a period of two weeks in which to make the necessary corrections. Should the defects be of an emergency nature, which in the opinion of the **CITY OF GALLLATIN** requires immediate correction, the **CONTRACTOR** will be notified and requested to make the necessary repairs immediately. Should this be impractical or if the **CONTRACTOR** should fail to respond to the request for corrective action within the specified period, the **CITY OF GALLLATIN** may proceed to have the defects corrected and shall bill the **CONTRACTOR** for all charges in connection therewith, including labor, lost water, materials and equipment rental. Such charges may be deducted from amounts due the **CONTRACTOR** if any of the **CONTRACTOR'S** money has been withheld. In the event the **CONTRACTOR** fails, refuses or neglects to pay the **CITY OF GALLLATIN** the surety shall be liable for such charges.
- 9.02 **MAINTENANCE OBLIGATION** - The **CONTRACTOR** shall be fully responsible for maintenance of any and all portions of the work, which he performs under this contract for a period of 90 days. This maintenance obligation shall begin upon formal acceptance of the project and is intended to place a limit upon the **CONTRACTOR'S** responsibility for normal maintenance required for the routine operation of the system. This 90 day obligation shall not be construed as relieving the **CONTRACTOR** of the responsibility for maintenance or repair work resulting from defective materials or workmanship.

**SECTION 10 - MEASUREMENT AND PAYMENT (BID WORK ONLY)****10.01 GENERAL**

The **CONTRACTOR** shall furnish all labor, tools, equipment, and materials to construct the proposed improvements complete as shown on the Plans and described in these specifications. The work shall be measured for payment in accordance with applicable provisions of these specifications and payment shall be made on the basis of the unit prices or lump sum prices bid. The sum of the payments for eligible pay items contained in the proposal form shall be the compensation to be paid for the completed project; provided however, that changes in the work covered by written change orders, properly executed may result in additions or deductions from the contract price.

The **CONTRACTOR'S** attention is called to the fact that although the pay items shown shall be the basis for establishing the contract price, the pay items do not necessarily reflect the total amount of work to be performed. The cost of incidental work such as clearing and grubbing, trenching, backfilling, testing, etc. which is necessary but which is not specifically listed as one of the pay items, shall be included in the prices bid for the eligible pay items to which the incidental work is most closely related.

**10.02 WATER LINES**

a. **Measurement** - Measurement for the length of pipe to be included for payment at the unit prices bid shall be the actual length laid in the trench measured along the centerline of the pipe and including the lengths of valves and fittings in the line. Measurement shall begin at the ends of existing pipes, valves or fittings to which the new pipe is connected or such other point as may be designated on the Plans.

b. **Payment** - Payment for installing only water pipe lines complete will be made at the contract unit price bid per linear foot for water pipe of the various sizes and classifications. Payment for installing water pipe shall constitute full compensation for trenching, rock excavation, crushed stone bedding and crushed stone backfill to 12" above pipe where rock excavation is encountered, installation, backfill, disinfecting and testing for the water line, together with other incidental and related work necessary for the completion of the water main installation except that fittings, valves, valve boxes, pavement replacement and such other items shall be paid for separately, if included as a pay item on the bid proposal.

**10.03 FITTINGS**

a. **Measurement** - Pipe fittings for cast iron, ductile iron, AC or PVC pipe will be measured for payment by multiplying the number of fittings in each classification by the standard weight of the fitting as shown in appropriate tables of ANSI specification A21.10, American Standard for Cast Iron Fittings 2" through 48" for water and other liquids. Weights of fittings shall be exclusive of gland, bolts, gaskets, or other appurtenances and shall be as shown in the above specification rather than actual invoice weights.

b. **Payment** - Payment for installing only pipe fittings complete in accordance with these specifications will be made on the basis of contract unit price bid per pound for pipe fittings (all fittings assumed to be cast iron for purpose of determining weight as noted above) and shall constitute compensation in full for installing the fittings together with all incidental and related work except as specifically covered by other pay items.

**10.04 VALVES**

- a. **Measurement** - Valves will be measured by actual count of each size and type of valve installed in the completed system.
- b. **Payment** - Payment for installing only valves of the various sizes and classifications, together with any necessary joint accessories, adapters, extension stems, or other required appurtenances, shall be made on the basis of the contract unit prices bid. Such payment shall constitute full compensation for installing the valves complete in full accordance with the Plans and Specifications.

**10.05 VALVE BOXES**

- a. **Measurement** - Measurement of valve boxes for payment shall be made by actual count of valve boxes provided in the completed installation.
- b. **Payment** - Payment for installing only valve boxes complete with lids, extensions, crushed stone and other appurtenances as required shall be based on the contract unit prices bid. Such payment shall constitute compensation in full for installing the valve boxes complete in full accordance with the Plans and Specifications.

**10.06 FIRE HYDRANTS**

- a. **Measurement** - Measurement of fire hydrants for payment shall be made by actual count of fire hydrants provided in the completed installation.
- b. **Payment** - Payment for installing fire hydrants complete shall be based on the contract unit prices bid. Such payment shall constitute compensation in full for installing the existing fire hydrant complete with the necessary barrel and stem extensions, concrete base and kicker and the required crushed stone for drainage.

**10.07 ROCK EXCAVATION**

Excavation is unclassified; therefore, separate measurement or payment will not be made.

**10.08 CLASS B CONCRETE**

- a. **Measurement** - Class B concrete used in bracing pipe and fittings shall be measured for payment on the basis of the theoretical quantities required to provide the desired bearing area with a trench of the desired dimensions. The pay quantities for braces behind typical fittings shall be as follows:

10.08 **CLASS B CONCRETE** (continued)**PAY QUANTITIES FOR THRUST BLOCKS - CF CLASS B CONCRETE**

<b><u>PIPE DIA.</u></b>	<b><u>TEE</u></b>	<b><u>90°</u></b>	<b><u>45°</u></b>	<b><u>22.5°</u></b>	<b><u>DEAD END</u></b>
6" or less	2.00	4.60	1.94	1.94	7.1
8"	4.17	6.55	3.08	3.08	11.46
10"	7.50	8.98	4.60	4.60	14.95
12"	14.00	21.13	8.98	6.55	20.28
16"	29.33	36.80	15.53	8.98	32.20
20"	54.17	78.27	32.20	15.53	41.57
24"	96.00	140.88	57.50	24.65	55.60
30"	180.00	279.45	109.32	36.80	87.00

In the event the type of soil is such that the bearing area must be increased, an appropriate adjustment will be made in the pay quantities; the adjustment being equal to the percentage adjustment in the bearing area required. For concrete used in over bends in the pipeline where no specified dimensions are shown for the thrust block, the measurement will be based on the actual quantity of concrete which the **ENGINEER** directs the **CONTRACTOR** to use.

b. **Payment** - Payment for Class B concrete shall be made on the basis of the unit price bid per cubic yard, and shall constitute full compensation for excavation, forming, furnishing and placing the concrete, and other incidental work required to complete the work. No separate payment will be made for Class B concrete included in fire hydrant bracing, or other structures where the price of such concrete is included in the unit price or lump sum price bid for the item.

10.09 **PAVEMENT REPLACEMENT**

a. **Measurement** - Measurement for pavement replacement shall be equal to the length of the pavement cut multiplied by the width of pavement actually replaced within a strip having a maximum width equal to the nominal pipe diameter plus 3'-6" centered over the pipe line. For pavement replacement on State or Federal highways where concrete base is required, the maximum pay width will be increased to 7'-6".

b. **Payment** - Payment for pavement replacement shall be made on the basis of the unit prices bid for various classifications of pavement as indicated in the proposal form. Such payment shall constitute full compensation for furnishing all labor, materials and equipment and replacing the damaged pavement, including the crushed stone base as required. The **CONTRACTOR** is advised that although the limits of payment shall be as described under paragraph (a) above he shall be responsible for replacing all pavement damaged during construction, so that the paved area is left in a condition as good as or better than before the start of construction.

Payment for pavement replacement shall also include compensation for providing temporary pavement patches until such time as the permanent pavement is placed inasmuch as no separate payment will be made for this work.

#### 10.10 **CRUSHED STONE**

a. **Measurement** - Measurement of crushed stone for payment shall be based on weight, but in certain instances as outlined below, volume computations will be used to determine the eligible pay weight. In all other cases delivery tickets shall be furnished to the **ENGINEER** at the time of placement. Crushed stone used for bedding water mains in rock excavation or in backfill of water lines to a point twelve inches (12") above pipe and backfill around fire hydrants and valves shall not be measured for payment. Payment shall be included in the unit price for pipe, valves or fire hydrant.

Crushed stone used as base material for pavement replacement also will not be measured for payment inasmuch as payment for this material will be included in the payment for pavement replacement.

Crushed stone used in trench backfill under traveled areas will be measured for payment as follows:

- a. Eligible width equal to 18" plus nominal diameter.
- b. Eligible depth shall be measured vertically from a point 6" above top of pipe to bottom of crushed stone pavement base.
- c. Eligible length equal to length of water main under traveled area, plus the eligible depth under (b) above, (to allow for slope at ends).
- d. Volume as determined from the product of length times width times depth to be multiplied by 150 pounds per cubic foot to determine weight of crushed stone for payment.

Crushed stone required for maintenance of unpaved drives, roads, shoulders shall be at the **CONTRACTOR'S** expense and will not be measured for payment.

b. **Payment** - Payment for crushed stone, measured as provided above, which payment shall constitute full compensation for furnishing, hauling, placing and compacting the stone as specified.

#### 10.11 **CONNECTIONS TO EXISTING LINES**

a. **Measurement** - Measurement for connection to existing via removal of an existing hydrant and connecting to the existing main shall be per each connection made by this method and shall include, but not be limited to, all labor associated with the removal of the existing hydrant, any fittings or other ancillary materials needed, and all dewatering, additional bracing and labor needed to make the necessary connection to the existing main. .

b. **Payment** - Payment shall be made on the basis of the applicable unit price bid for each connection made by this method. This price shall constitute payment for furnishing all labor, tools and equipment, crushed stone, fittings, rock or earth excavation, dewatering and all other appurtenances required to complete this connection type.

#### 10.12 **CASING PIPE**

a. **Measurement** - Measurement of casing pipe installed under pavement, railroad tracks, structures or other places shall be by the linear foot and shall be the centerline length of casing installed and accepted.

b. **Payment** - Payment shall be made on the basis of the application unit price bid for various diameters and for various methods of installation. This price shall constitute payment for furnishing and installing casing pipe by boring and jacking or by excavation and backfilling, whichever is shown on the Plans or directed by the **ENGINEER**, including all labor, tools and equipment, crushed stone, boring, rock excavation, rock boring, and pavement replacement required (water pipe shall be paid for at applicable unit price bid).

#### 10.13 **BORE AND JACK WATER LINE**

a. **Measurement** - Measurement of casing pipe installed under pavement, railroad tracks or other places by boring and jacking shall be measured by the linear foot and shall be the centerline length of pipe installed and accepted.

b. **Payment** - Main water lines laid by the boring and jacking method shall be paid for at the unit price bid for installing pipe of various diameters. This price shall include all labor, tools, and equipment (except as noted above) necessary to complete the items. No extra compensation shall be paid for service line by Bore and Jack.

#### 10.14 **NEW SERVICE CONNECTIONS**

a. **Measurement** - Service connections will be measured by an actual count of each size and type of service installed, tested, disinfected and accepted. The unit price bid for this item shall include saddles, corporation stop, curb stops, yoke, meter box, water pressure regulator etc., as covered by Specifications and Plans.

b. **Payment** - Service connections assemblies placed and accepted, measured as provided above, will be paid for at the contract unit price per each, which price and payment shall constitute full compensation for furnishing, hauling and installing complete, testing and disinfection, for excavation, preparation of bed and backfilling, and for the furnishing of all equipment, tools, and incidentals necessary to complete the item.

#### 10.15 **STANDARD BLOW-OFFS**

a. **Measurement** - Standard blow-offs include 2" tapped plug, 2" gate valve, 2" bronze pipe, meter box, concrete brace, #77 mainguard hydrant, and 2" fittings. This item will be measured by an actual count of blow-offs installed, tested, sterilized and accepted.

b. **Payment** - Standard blow-off assemblies, installed and accepted will be paid for on the basis of the unit price per each and payment shall constitute full compensation for furnishing, hauling, installing complete, testing and sterilizing, for excavation, preparation of bed and backfilling, and for the furnishing of all equipment, tools and incidentals necessary to complete the item.

**10.16 SERVICE RELOCATIONS AND RECONNECTIONS**

a. **Measurement** - Service relocations will be measured by an actual count of each installed and accepted. The unit price bid for this item shall include tapping new mains, corporation stop, curb stop, yokes, meter box, and other fittings as covered by Specifications and Plans.

b. **Payment** - Services relocated and accepted will be paid for on the basis of the unit price per each and payment shall constitute full compensation for furnishing all materials, installing, excavation, and for the furnishing of all equipment, tools, labor and incidentals necessary to complete the item.

**10.17 SERVICE LINE RECONNECTIONS**

a. **Measurement** - Service reconnections will be measured by an actual count of each installed and accepted. The unit price bid for this item shall include tapping new mains, corporation stop, location of the existing service line from the existing main and reconnection to existing service using a compression fitting.

b. **Payment** - Services relocated and accepted will be paid for on the basis of the unit price per each and payment shall constitute full compensation for furnishing all materials, installing, excavation, and for the furnishing of all equipment, tools, labor and incidentals necessary to complete the item.

**10.18 SERVICE PIPE**

a. **Measurement** – Measurement for the length of service pipe used for service installations and service relocations included for payment at the unit prices bid shall be the actual length installed and measured from the main to center of the meter box without deductions for meter couplings, and curb stops, etc.

b. **Payment** – Payment for installing only water service lines completed will be made at the contract unit price bid per linear foot for water service pipe of the various sizes, types and classifications. Payment for installing service pipe shall constitute full compensation for excavation, installation, road borings with 2" PVC casing, backfill, disinfecting, testing, and other incidentals and related work necessary for the completion of the bid item.

**10.19 AIR RELEASE VALVE ASSEMBLY**

a. **Measurement** – Air release valve assemblies will be measured by an actual count of each size and type installed and accepted. The unit price bid for this item shall include tapping the main saddle, corporation stop, bronze gate valve, air release valve, manhole and cover, crushed stone and other fittings as covered by Specifications and Plans.

b. **Payment** – Air release valve assemblies installed and accepted will be paid on the basis of the unit price per each and payment shall constitute full compensation for furnishing all materials and supplies, and installing complete, testing, excavation and for the furnishing of all equipment, tools and incidentals necessary to complete the item.

**10.20 WATER LINE EXTRA DEPTH**

No additional compensation will be made for Water Line Extra Depth excavation. The plans include a profile of the proposed facilities and contractor should be prepared to install the proposed facilities as shown on the plans.